

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209

08/15/2024 5:30 PM

SENSOR STATUS REPORT

SENSOR NO. 1
Ru1 Sump
OK

SENSOR NO. 2
Prem Sump
STANDARD SENSOR ACTIVE

SENSOR NO. 3
Ds1 Sump
OK

SENSOR NO. 4
Ru1 Prem Int
OK

SENSOR NO. 5
Ds1 Inters
OK

SENSOR NO. 6
SENSOR 6
OK

SENSOR NO. 7
SENSOR 7
OK

SENSOR NO. 8
SENSOR 8
OK

SENSOR NO. 9
SENSOR 9
OK

SENSOR NO. 10
SENSOR 10
OK

SENSOR NO. 11
SENSOR 11
OK

SENSOR NO. 12
SENSOR 12
OK

TANK COMPLIANCE
CVS TANK 1
SENSOR NO. 4

CVS TANK 2
SENSOR NO. 4

CVS TANK 3
SENSOR NO. 5

LINE COMPLIANCE
CVS LINE 1
SENSOR NO. 1

CVS LINE 2
SENSOR NO. 2

CVS LINE 3
SENSOR NO. 3

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209

08/15/2024 5:31 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

SENSORS

SENSOR 1	OPERATIONAL
SENSOR 2	TROUBLE
SENSOR 3	OPERATIONAL
SENSOR 4	OPERATIONAL

SENSOR 5	OPERATIONAL
SENSOR 6	OPERATIONAL
SENSOR 7	OPERATIONAL
SENSOR 8	OPERATIONAL
SENSOR 9	OPERATIONAL
SENSOR 10	OPERATIONAL
SENSOR 11	OPERATIONAL
SENSOR 12	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

TANK 1

08/14/2024	3:00 AM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH

08/09/2024	1:04 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

07/12/2024	12:15 AM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH

06/12/2024	11:12 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

05/13/2024 4:45 AM
LEAK TEST 0,20 GPH
SLOPE -0,08 GPH

04/13/2024 1:42 AM
LEAK TEST 0,20 GPH
SLOPE -0,05 GPH

03/14/2024 11:33 PM
LEAK TEST 0,20 GPH
SLOPE 0,05 GPH

02/13/2024 6:21 AM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

01/14/2024 6:48 AM
LEAK TEST 0,20 GPH
SLOPE -0,03 GPH

12/19/2023 10:59 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

11/19/2023 6:09 AM
LEAK TEST 0,20 GPH
SLOPE -0,10 GPH

10/22/2023 7:39 AM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

09/23/2023 11:33 PM
LEAK TEST 0,20 GPH
SLOPE -0,05 GPH

08/24/2023 11:51 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

07/25/2023 11:38 PM
LEAK TEST 0,20 GPH
SLOPE 0,05 GPH

TANK 2

08/15/2024 1:10 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

07/16/2024 10:51 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

06/16/2024 11:13 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

05/17/2024 10:16 PM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

04/17/2024 11:43 PM
LEAK TEST 0,20 GPH
SLOPE -0,03 GPH

03/18/2024 10:10 PM
LEAK TEST 0,20 GPH
SLOPE 0,04 GPH

02/17/2024 11:34 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

01/18/2024 11:38 PM
LEAK TEST 0,20 GPH
SLOPE -0,02 GPH

12/19/2023 9:51 PM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

11/19/2023 6:24 AM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

10/20/2023 10:59 PM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

09/20/2023 8:33 AM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

08/21/2023 11:30 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

07/22/2023 10:32 PM
LEAK TEST 0,20 GPH
SLOPE -0,02 GPH

TANK 3

08/15/2024 4:36 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

08/06/2024 11:37 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

07/07/2024 11:34 PM
LEAK TEST 0,20 GPH
SLOPE 0,03 GPH

06/07/2024 9:58 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

05/08/2024 10:37 PM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

04/08/2024 11:53 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

03/09/2024 10:48 PM
LEAK TEST 0,20 GPH
SLOPE -0,00 GPH

02/08/2024 11:30 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

01/09/2024 11:12 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

12/10/2023 10:37 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

11/10/2023 11:49 PM
LEAK TEST 0,20 GPH
SLOPE 0,04 GPH

10/11/2023 11:14 PM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

09/11/2023 11:55 PM
LEAK TEST 0,20 GPH
SLOPE 0,03 GPH

08/12/2023 10:36 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

CVS TANKS
PASSED SENSOR
COMPLIANCE TESTS

CVS TANK 1

08/15/2024 12:00 PM
SENSOR NO. 4
Rul Prem Int

08/08/2024 12:00 PM
SENSOR NO. 4
Rul Prem Int

07/09/2024 12:00 PM
SENSOR NO. 4
Rul Prem Int

05/10/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
04/10/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
03/11/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
02/10/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
01/11/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
12/12/2023 SENSOR NO. 4 Rul Prem Int	12:00 PM
11/12/2023 SENSOR NO. 4 Rul Prem Int	12:00 PM
10/13/2023 SENSOR NO. 4 Rul Prem Int	12:00 PM
09/13/2023 SENSOR NO. 4 Rul Prem Int	12:00 PM
08/14/2023 SENSOR NO. 4 Rul Prem Int	12:00 PM
CVS TANK 2	
08/15/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
08/08/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
07/09/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
06/09/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
05/10/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
04/10/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
03/11/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
02/10/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
01/11/2024 SENSOR NO. 4 Rul Prem Int	12:00 PM
12/12/2023 SENSOR NO. 4 Rul Prem Int	12:00 PM
11/12/2023 SENSOR NO. 4 Rul Prem Int	12:00 PM
10/13/2023 SENSOR NO. 4 Rul Prem Int	12:00 PM

09/13/2023	12:00 PM
SENSOR NO. 4	
Ru1 Prem Int	
08/14/2023	12:00 PM
SENSOR NO. 4	
Ru1 Prem Int	
CVS TANK 3	
08/15/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
08/13/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
07/14/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
06/14/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
05/15/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
04/15/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
03/16/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
02/15/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
01/16/2024	12:00 PM
SENSOR NO. 5	
Dsl Inters	
12/17/2023	12:00 PM
SENSOR NO. 5	
Dsl Inters	
11/17/2023	12:00 PM
SENSOR NO. 5	
Dsl Inters	
10/18/2023	12:00 PM
SENSOR NO. 5	
Dsl Inters	
09/18/2023	12:00 PM
SENSOR NO. 5	
Dsl Inters	
08/19/2023	12:00 PM
SENSOR NO. 5	
Dsl Inters	
07/20/2023	12:00 PM
SENSOR NO. 5	
Dsl Inters	
CVS LINES PASSED SENSOR COMPLIANCE TESTS	
CVS LINE 1	
08/15/2024	12:00 PM
SENSOR NO. 1	
Ru1 Sump	
08/02/2024	12:00 PM
SENSOR NO. 1	
Ru1 Sump	
07/03/2024	12:00 PM
SENSOR NO. 1	
Ru1 Sump	
06/03/2024	12:00 PM
SENSOR NO. 1	
Ru1 Sump	
05/04/2024	12:00 PM
SENSOR NO. 1	
Ru1 Sump	
04/04/2024	12:00 PM
SENSOR NO. 1	
Ru1 Sump	