

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 18662

Contact Number

Facility Name MARATHON

Contact email

Address 3901 S Main St, Elkhart, IN 46516

Date of Inspection 07/19/23

Operator on Duty Name

Name of the Person Conducting Inspection AKSHIT SHARMA

Operator Training current

Operator Training ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection ☒ ATG ☐ TIM ☐ SIR ☐ IC ☐ Other

Make and Model

Does it have paper?

FFS TS1601 Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

☐ Yes ☐ No Operator Notified ☒ Yes ☐ No

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?

☐ Yes ☒ No Operator Notified ☒ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Piping/STP Sumps

Are Sumps Clean and free from water, debris, product etc?

☐ Yes ☒ No Operator Notified ☒ Yes ☐ No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

☐ Yes ☒ No Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com