

10/28/2024 5:26 PM
DUNLAP MARATHON
MISHAWKA RD
DUNLAP IN
S/N 131209

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209

10/28/2024 5:26 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-RDM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CFM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

SENSORS

SENSOR 1	OPERATIONAL
SENSOR 2	TROUBLE
SENSOR 3	OPERATIONAL
SENSOR 4	OPERATIONAL
SENSOR 5	OPERATIONAL
SENSOR 6	OPERATIONAL
SENSOR 7	OPERATIONAL
SENSOR 8	OPERATIONAL
SENSOR 9	OPERATIONAL
SENSOR 10	OPERATIONAL
SENSOR 11	OPERATIONAL
SENSOR 12	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

TANK 1

10/28/2024	4:46 AM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH

10/08/2024	5:06 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

09/08/2024	9:02 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

08/09/2024	1:04 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

07/12/2024	12:15 AM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH

06/12/2024	11:12 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

TANK 1		
05/13/2024	8:45 AM	
LEAK TEST	0,20 GPH	
SLOPE	-0,08 GPH	
04/13/2024	1:42 AM	
LEAK TEST	0,20 GPH	
SLOPE	-0,05 GPH	
03/14/2024	11:33 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,05 GPH	
02/13/2024	6:21 AM	
LEAK TEST	0,20 GPH	
SLOPE	0,02 GPH	
01/14/2024	6:48 AM	
LEAK TEST	0,20 GPH	
SLOPE	-0,03 GPH	
12/19/2023	10:59 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,01 GPH	
11/19/2023	6:09 AM	
LEAK TEST	0,20 GPH	
SLOPE	-0,10 GPH	
10/22/2023	7:39 AM	
LEAK TEST	0,20 GPH	
SLOPE	0,00 GPH	
TANK 2		
10/28/2024	4:08 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,01 GPH	
10/14/2024	10:57 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,01 GPH	
09/14/2024	8:33 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,02 GPH	
08/15/2024	10:03 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,00 GPH	
07/16/2024	10:51 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,01 GPH	
06/16/2024	11:13 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,01 GPH	
05/17/2024	10:16 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,00 GPH	
04/17/2024	11:43 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,03 GPH	
03/18/2024	10:10 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,04 GPH	
02/17/2024	11:34 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,01 GPH	
01/18/2024	11:38 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,02 GPH	
12/19/2023	9:51 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,00 GPH	
11/19/2023	6:24 AM	
LEAK TEST	0,20 GPH	
SLOPE	0,00 GPH	
10/20/2023	10:59 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,00 GPH	
TANK 3		
10/28/2024	3:00 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,01 GPH	
10/05/2024	10:01 PM	
LEAK TEST	0,20 GPH	
SLOPE	0,01 GPH	
09/05/2024	11:35 PM	
LEAK TEST	0,20 GPH	
SLOPE	-0,02 GPH	

COMPLIANCE TESTS	
PASSED SENSOR	
COMPLIANCE TESTS	
CVS TANKS	
PASSED SENSOR	
COMPLIANCE TESTS	
CVS TANK 1	
08/06/2024	11:37 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
07/07/2024	11:34 PM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH
06/07/2024	9:58 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
05/08/2024	10:37 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
04/08/2024	11:53 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
03/09/2024	10:48 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH
02/08/2024	11:30 PM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH
01/09/2024	11:12 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
12/10/2023	10:37 PM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH
11/10/2023	11:49 PM
LEAK TEST	0,20 GPH
SLOPE	0,04 GPH
10/11/2023	11:14 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
CVS TANKS	
PASSED SENSOR	
COMPLIANCE TESTS	
CVS TANK 1	
10/26/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
10/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
09/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
08/08/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
07/09/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
06/09/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
05/10/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
04/10/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
03/11/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
02/10/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
01/11/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
12/12/2023	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
12/12/2023	12:00 PM

CVS TANK 2		
10/28/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
10/07/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
09/07/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
08/08/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
07/09/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
06/09/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
05/10/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
04/10/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
03/11/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
02/10/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
01/11/2024	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
12/12/2023	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
11/12/2023	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
10/13/2023	12:00 PM	
SENSOR NO. 4		
Rul Prem Int		
CVS TANK 3		
10/28/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
10/12/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
09/12/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
08/13/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
07/14/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
06/14/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
05/15/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
04/15/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
03/16/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
02/15/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
01/16/2024	12:00 PM	
SENSOR NO. 5		
Dsl Inters		
12/17/2023	12:00 PM	
SENSOR NO. 5		
Dsl Inters		

11/17/2023 12:00 PM
SENSOR NO. 5
Ds1 Inters

10/18/2023 12:00 PM
SENSOR NO. 5
Ds1 Inters

CVS LINES
PASSED SENSOR
COMPLIANCE TESTS

CVS LINE 1
10/28/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

10/01/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

09/01/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

08/02/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

07/03/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

06/03/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

05/04/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

04/04/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

03/05/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

02/04/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

01/05/2024 12:00 PM
SENSOR NO. 1
Ru1 Sump

12/06/2023 12:00 PM
SENSOR NO. 1
Ru1 Sump

11/06/2023 12:00 PM
SENSOR NO. 1
Ru1 Sump

10/07/2023 12:00 PM
SENSOR NO. 1
Ru1 Sump

CVS LINE 2
09/29/2022 12:00 PM
SENSOR NO. 2
Prem Sump

CVS LINE 3
10/28/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

10/07/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

09/07/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

08/08/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

07/09/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

06/09/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

05/10/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

04/10/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

03/11/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

02/10/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

01/11/2024 12:00 PM
SENSOR NO. 3
Ds1 Sump

12/12/2023 12:00 PM
SENSOR NO. 3
Ds1 Sump

11/12/2023 12:00 PM
SENSOR NO. 3
Ds1 Sump

10/13/2023 12:00 PM
SENSOR NO. 3
Ds1 Sump

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209

10/28/2024 5:28 PM

SENSOR STATUS REPORT

SENSOR NO. 1
Ru1 Sump
OK

SENSOR NO. 2
Prem Sump
STANDARD SENSOR ACTIVE

SENSOR NO. 3
Ds1 Sump
OK

SENSOR NO. 4
Ru1 Prem Int
OK

SENSOR NO. 5
Ds1 Inters
OK

SENSOR NO. 6
SENSOR 6
OK

SENSOR NO. 7
SENSOR 7
OK

SENSOR NO. 8
SENSOR 8
OK

SENSOR NO. 9
SENSOR 9
OK

SENSOR NO. 10
SENSOR 10
OK

SENSOR NO. 11
SENSOR 11
OK

SENSOR NO. 12
SENSOR 12
OK

TANK COMPLIANCE
CVS TANK 1
SENSOR NO. 4

CVS TANK 2
SENSOR NO. 4

CVS TANK 3
SENSOR NO. 5

LINE COMPLIANCE
CVS LINE 1
SENSOR NO. 1

CVS LINE 2
SENSOR NO. 2

CVS LINE 3
SENSOR NO. 3