

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209
05/25/2025 7:14 PM
LEAK TEST REPORT
RUL 15041.0 GAL
Unleaded
END TIME 9:46 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON DISPENSE
PREM 7099.0 GAL
Premium
END TIME 9:53 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON DISPENSE
DSL 7899.0 GAL
Diesel
END TIME 9:47 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON MINIMUM LEVEL

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209
05/25/2025 7:14 PM
LEAK TEST REPORT

RUL 15041.0 GAL
Unleaded
END TIME 9:46 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON DISPENSE
PREM 7099.0 GAL
Premium
END TIME 9:53 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON DISPENSE
DSL 7899.0 GAL
Diesel
END TIME 9:47 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON MINIMUM LEVEL

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209
05/25/2025 7:14 PM
LEAK ESTIMATE REPORT

RUL
LEAK TEST 0.200 GPH
CONFIDENCE LEVEL 99.0%
GROSS CAPACITY 28.4%
GROSS 4268.6 GAL
NET 4272.3 GAL
LEVEL 39.471 IN
TEMP 58.773 F
WATER VOL 0.0 GAL
WATER LEVEL 0.030 IN
EST TIME 5 HRS 50 MIN
PREM
LEAK TEST 0.200 GPH
CONFIDENCE LEVEL 99.0%
GROSS CAPACITY 13.1%
GROSS 927.4 GAL
NET 928.7 GAL
LEVEL 22.101 IN
TEMP 57.786 F
WATER VOL 0.1 GAL
WATER LEVEL 0.043 IN
EST TIME 2 HRS 10 MIN
DSL
LEAK TEST 0.200 GPH
CONFIDENCE LEVEL 99.0%
GROSS CAPACITY 15.0%
GROSS 1182.5 GAL
NET 1183.0 GAL
LEVEL 19.302 IN
TEMP 58.996 F
WATER VOL 0.0 GAL
WATER LEVEL 0.000 IN
EST TIME 3 HRS 20 MIN