

Dunlap Marathon
Mishawaka Rd
Dunlap IN
S/N 131209

06/26/2025 8:51 PM

SENSOR STATUS REPORT

SENSOR NO. 1
Rul Sump
OK

SENSOR NO. 2
Prim Sump
ACTIVE

SENSOR NO. 3
Ds1 Sump
OK

SENSOR NO. 4
Rul Prem Int
OK

SENSOR NO. 5
Ds1 Inters
OK

SENSOR NO. 6
SENSOR 6
OK

SENSOR NO. 7
SENSOR 7
OK

SENSOR NO. 8
SENSOR 8
OK

SENSOR NO. 9
SENSOR 9
OK

SENSOR NO. 10
SENSOR 10
OK

SENSOR NO. 11
SENSOR 11
OK

SENSOR NO. 12
SENSOR 12
OK

TANK COMPLIANCE

CVS TANK 1
SENSOR NO. 4

CVS TANK 2
SENSOR NO. 4

CVS TANK 3
SENSOR NO. 5

LINE COMPLIANCE

CVS LINE 1
SENSOR NO. 1

CVS LINE 2
SENSOR NO. 2

CVS LINE 3
SENSOR NO. 3

Dunlap Marathon
Mishawaka Rd
Dunlap IN
S/N 131209

06/26/2025 9:52 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM NOT INSTALLED

TS-ROM NOT INSTALLED

TS-SEM 1 NOT INSTALLED

TS-SEM 2 NOT INSTALLED

TS-CPM NOT INSTALLED

PRINTER OPERATIONAL

FAX/MOD OPERATIONAL

PROBES

PROBE 1 OPERATIONAL

PROBE 2 OPERATIONAL

PROBE 3 OPERATIONAL

SENSORS

SENSOR 1 OPERATIONAL

SENSOR 2 TROUBLE

SENSOR 3 OPERATIONAL

SENSOR 4 OPERATIONAL

AUXILIARY INPUTS

AUX IN 1 OPERATIONAL

AUX IN 2 OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

1 11:00 AM

TS-SEM 2	NOT INSTALLED
TS-CPM	OPERATIONAL
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL
PROBES	
PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
SENSORS	
SENSOR 1	OPERATIONAL
SENSOR 2	TRUBLE
SENSOR 3	OPERATIONAL
SENSOR 4	OPERATIONAL
AUXILIARY INPUTS	
AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL
PASSED LEAK TESTS	
TANK 1	
NO DATA	
TANK 2	
NO DATA	
TANK 3	
NO DATA	
PASSED SCALO TESTS	
TANK 1	
06/26/2025	4:00 AM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH
06/12/2025	10:53 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
05/13/2025	3:00 AM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH
04/13/2025	11:41 PM
LEAK TEST	0.20 GPH
SLOPE	0.06 GPH
03/14/2025	6:28 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
02/12/2025	9:41 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH
01/13/2025	4:03 AM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH
12/16/2024	1:12 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
11/21/2024	2:46 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
11/07/2024	6:04 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
10/08/2024	5:06 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
09/08/2024	9:02 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
08/09/2024	1:04 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
07/12/2024	12:15 AM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH
06/12/2024	11:12 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
TANK 2	
06/26/2025	8:22 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
06/09/2025	10:03 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
05/10/2025	8:57 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
04/10/2025	10:14 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
03/11/2025	10:05 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
02/09/2025	2:53 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
01/10/2025	11:40 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
12/11/2024	12:19 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
11/13/2024	11:01 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
10/14/2024	10:57 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
09/14/2024	8:33 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
08/15/2024	10:03 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
07/16/2024	10:51 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
06/16/2024	11:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
TANK 3	
06/26/2025	9:03 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
06/02/2025	11:42 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
05/03/2025	10:45 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
04/03/2025	10:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
03/04/2025	11:52 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
02/02/2025	11:39 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
01/03/2025	9:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
12/04/2024	11:52 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
11/04/2024	10:48 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
10/05/2024	10:01 PM
LEAK TEST	0.20 GPH

12/11/2024	12:19 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
11/13/2024	11:01 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
10/14/2024	10:57 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
09/14/2024	8:33 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
08/15/2024	10:03 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
07/16/2024	10:51 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
06/16/2024	11:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
TANK 3	
06/26/2025	9:03 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
06/02/2025	11:42 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
05/03/2025	10:45 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
04/03/2025	10:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
03/04/2025	11:52 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
02/02/2025	11:39 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
01/03/2025	9:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
12/04/2024	11:52 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
11/04/2024	10:48 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
10/05/2024	10:01 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
09/05/2024	11:35 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
08/06/2024	11:37 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
07/07/2024	11:34 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
06/07/2024	9:58 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

CVS TANKS
PASSED SENSOR
COMPLIANCE TESTS

CVS TANK 1	
06/26/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
06/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
05/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
04/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
03/06/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
02/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
01/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
12/06/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
11/06/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
10/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
09/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
08/08/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
07/09/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
06/09/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
CVS TANK 2	
06/26/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
06/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
05/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
04/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
03/06/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
02/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
01/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
12/06/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
11/06/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
10/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
09/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
08/08/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
07/09/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
06/09/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	