

SENSOR NO. 4
OK
SENSOR NO. 5
OK
SENSOR NO. 6
OK
SENSOR NO. 7
OK
SENSOR NO. 8
OK
SENSOR NO. 9
OK
SENSOR NO. 10
OK
SENSOR NO. 11
OK
SENSOR NO. 12
OK
TANK COMPLIANCE
CVS TANK 1
SENSOR NO. 4
CVS TANK 2
SENSOR NO. 4
CVS TANK 3
SENSOR NO. 5
LINE COMPLIANCE
CVS LINE 1
SENSOR NO. 1
CVS LINE 2
SENSOR NO. 2
CVS LINE 3
SENSOR NO. 3
Dunlap Marathon
Mishawaka Rd
Dunlap IN
S/N 131209
09/29/2025 12:23 PM
REGULATORY REPORT
HARDWARE STATUS
TS-CIM NOT INSTALLED
TS-ROM NOT INSTALLED
TS-SEM 1 NOT INSTALLED
TS-SEM 2 NOT INSTALLED
TS-CPM NOT INSTALLED
PRINTER OPERATIONAL
FAX/MOD OPERATIONAL
PROBES
PROBE 1 OPERATIONAL
PROBE 2 OPERATIONAL
PROBE 3 OPERATIONAL
SENSORS
SENSOR 1 OPERATIONAL
SENSOR 2 TROUBLE
SENSOR 3 OPERATIONAL
SENSOR 4 OPERATIONAL
SENSOR 5 OPERATIONAL
SENSOR 6 OPERATIONAL
SENSOR 7 OPERATIONAL
SENSOR 8 OPERATIONAL
SENSOR 9 OPERATIONAL
SENSOR 10 OPERATIONAL
SENSOR 11 OPERATIONAL
SENSOR 12 OPERATIONAL
AUXILIARY INPUTS
AUX IN 1 OPERATIONAL
AUX IN 2 OPERATIONAL
PASSED LEAK TESTS
TANK 1
NO DATA
TANK 2
NO DATA
TANK 3
NO DATA
PASSED SCALD TESTS
TANK 1
09/29/2025 5:11 AM
LEAK TEST 0.20 GPH
SLOPE -0.08 GPH
09/10/2025 9:36 AM
LEAK TEST 0.20 GPH
SLOPE -0.06 GPH
08/11/2025 5:04 AM
LEAK TEST 0.20 GPH
SLOPE -0.08 GPH
07/12/2025 3:03 AM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH
06/12/2025 10:53 PM
LEAK TEST 0.20 GPH
SLOPE 0.03 GPH
05/13/2025 3:00 AM
LEAK TEST 0.20 GPH
SLOPE -0.10 GPH
04/13/2025 11:41 PM
LEAK TEST 0.20 GPH
SLOPE 0.06 GPH
03/14/2025 6:28 AM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH
02/12/2025 9:41 PM
LEAK TEST 0.20 GPH
SLOPE -0.05 GPH
01/13/2025 4:03 AM
LEAK TEST 0.20 GPH
SLOPE -0.06 GPH
12/16/2024 1:12 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
11/21/2024 2:46 AM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH
11/07/2024 6:04 AM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH
10/08/2024 5:06 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
09/08/2024 9:02 PM
LEAK TEST 0.20 GPH
SLOPE -0.02 GPH
TANK 2
09/29/2025 10:48 AM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH
09/07/2025 10:14 PM
LEAK TEST 0.20 GPH
SLOPE -0.02 GPH
08/08/2025 11:31 PM
LEAK TEST 0.20 GPH
SLOPE -0.00 GPH
07/09/2025 11:12 PM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
06/09/2025 10:03 PM
LEAK TEST 0.20 GPH
SLOPE 0.03 GPH
05/10/2025 8:57 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH
04/10/2025 10:14 PM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH
03/11/2025 10:05 PM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
02/09/2025 2:53 PM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH

03/18/2025	0.20 GPM
LEAK TEST	-0.03 GPM
SLOPE	9:41 PM
02/12/2025	0.20 GPM
LEAK TEST	-0.05 GPM
SLOPE	4:03 AM
01/13/2025	0.20 GPM
LEAK TEST	-0.05 GPM
SLOPE	1:12 AM
12/16/2024	0.20 GPM
LEAK TEST	0.01 GPM
SLOPE	2:46 AM
11/21/2024	0.20 GPM
LEAK TEST	0.02 GPM
SLOPE	6:06 AM
11/01/2024	0.20 GPM
LEAK TEST	-0.01 GPM
SLOPE	5:06 AM
10/09/2024	0.20 GPM
LEAK TEST	0.01 GPM
SLOPE	8:02 PM
09/08/2024	0.20 GPM
LEAK TEST	-0.02 GPM
SLOPE	TANK 2
05/29/2025	10:08 AM
LEAK TEST	0.20 GPM
SLOPE	-0.08 GPM
04/01/2025	10:14 PM
LEAK TEST	0.20 GPM
SLOPE	-0.02 GPM
03/08/2025	11:31 PM
LEAK TEST	0.20 GPM
SLOPE	-0.00 GPM
01/09/2025	11:12 PM
LEAK TEST	0.20 GPM
SLOPE	0.01 GPM
06/08/2025	10:03 PM
LEAK TEST	0.20 GPM
SLOPE	0.03 GPM
05/10/2025	8:57 PM
LEAK TEST	0.20 GPM
SLOPE	0.00 GPM
04/10/2025	10:14 PM
LEAK TEST	0.20 GPM
SLOPE	-0.01 GPM
03/11/2025	10:05 PM
LEAK TEST	0.20 GPM
SLOPE	0.01 GPM
02/09/2025	2:53 PM
LEAK TEST	0.20 GPM
SLOPE	0.01 GPM
01/10/2025	11:40 PM
LEAK TEST	0.20 GPM
SLOPE	0.02 GPM
12/11/2024	12:19 PM
LEAK TEST	0.20 GPM
SLOPE	-0.03 GPM
11/13/2024	11:01 PM
LEAK TEST	0.20 GPM
SLOPE	0.01 GPM
10/14/2024	10:57 PM
LEAK TEST	0.20 GPM
SLOPE	-0.01 GPM
09/14/2024	8:33 PM
LEAK TEST	0.20 GPM
SLOPE	-0.02 GPM

TANK 3

09/29/2025	12:12 PM
LEAK TEST	0.20 GPM
SLOPE	0.08 GPM
06/31/2025	10:17 PM
LEAK TEST	0.20 GPM
SLOPE	-0.00 GPM
08/01/2025	11:55 PM
LEAK TEST	0.20 GPM
SLOPE	0.01 GPM
07/02/2025	11:16 PM
LEAK TEST	0.20 GPM
SLOPE	0.07 GPM
06/02/2025	11:42 PM
LEAK TEST	0.20 GPM
SLOPE	0.05 GPM
05/03/2025	10:45 PM
LEAK TEST	0.20 GPM
SLOPE	-0.01 GPM
04/03/2025	10:59 PM
LEAK TEST	0.20 GPM
SLOPE	0.01 GPM
03/04/2025	11:52 PM
LEAK TEST	0.20 GPM
SLOPE	-0.01 GPM
02/02/2025	11:39 PM
LEAK TEST	0.20 GPM
SLOPE	0.05 GPM
01/03/2025	9:13 PM
LEAK TEST	0.20 GPM
SLOPE	0.02 GPM
12/04/2024	11:52 PM
LEAK TEST	0.20 GPM
SLOPE	0.01 GPM
11/04/2024	10:48 PM
LEAK TEST	0.20 GPM
SLOPE	-0.03 GPM
10/05/2024	10:01 PM
LEAK TEST	0.20 GPM
SLOPE	0.01 GPM
09/05/2024	11:35 PM
LEAK TEST	0.20 GPM
SLOPE	-0.02 GPM

CVS TANKS PASSED SENSOR COMPLIANCE TESTS

CVS TANK 1

09/29/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
09/02/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
08/03/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
07/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
06/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
05/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
04/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
03/06/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
02/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
01/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
12/06/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
11/06/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
10/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
09/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	

CVS TANK 2

09/29/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
09/02/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
08/03/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
07/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
06/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
05/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
04/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
03/06/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
02/04/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
01/05/2025	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
12/06/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
11/06/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
10/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	
09/07/2024	12:00 PM
SENSOR NO. 4	
Rul Prem Int	

[illegible]