

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

MAY 19, 2023 1:30 PM

LEAK TEST RESULTS

MAY 19, 2023 1:30 PM

T 1:100L
PROBE SERIAL NUM 366199

0.2 OIL HP TEST
PER: MAY 19, 2023 PASS

T 2:1PLUS
PROBE SERIAL NUM 363200

0.2 OIL HP TEST
PER: MAY 19, 2023 PASS

T 3:PREMIUM
PROBE SERIAL NUM 366409

0.2 OIL HP TEST
PER: MAY 19, 2023 PASS

T 4:KEROSENE
PROBE SERIAL NUM 364080

0.2 OIL HP TEST
PER: MAY 19, 2023 PASS

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

MAY 19, 2023 1:30 PM

LEAK TEST REPORT

T 1:100L
PROBE SERIAL NUM 366199

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

MAY 19, 2023 1:30 PM

LEAK TEST REPORT

T 2:1PLUS
PROBE SERIAL NUM 363200

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

MAY 19, 2023 1:30 PM

LEAK TEST REPORT

T 3:PREMIUM
PROBE SERIAL NUM 366409

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

MAY 19, 2023 1:30 PM

LEAK TEST REPORT

T 4:KEROSENE
PROBE SERIAL NUM 364080

NO TEST DATA AVAILABLE

***** END *****