



PROFESSIONAL TANK INVESTIGATION CORP.

PO Box 80265 Saukville, WI 53080

www.protanic.com

(262) 268-1150

Site ID/Facility Name and Address				Test Date
2807				
S & Q Burger Dairy #25303				2022-09-28
4023 West Sample Street			+	
South Bend	+	IN	+	46619

Tank Tightness Test Results						
Product	State ID	Capacity	Construction	Volumetric Result	GPH Score	Ullage Result
Regular unleaded		12K	Steel	Pass	+0.0352 gph	Pass
Mid-Grade unleaded		8K	Steel	Pass	+0.0270 gph	Pass
Premium unleaded		4K	Steel	Pass	+0.0030 gph	Pass
Kerosene		2K	Steel	Pass	-0.0019 gph	Pass

Comments

Equipment Utilized	Equipment Detail and Certifications
Alert Tank Tester	Wis. Material Approval No. - 20170001

Technician Information		
Rod Botero		

Respectfully submitted,