



PROFESSIONAL TANK INVESTIGATION CORP.

PO Box 80265 Saukville, WI 53080

www.protanic.com

(262) 268-1150

Site ID/Facility Name and Address	Test Date
2807 S & Q Burger Dairy #25303 4023 West Sample Street South Bend IN 46619	2022-09-28

Line and Leak Detector Test Results						
Product	Piping System Type	Line Material	Precision Line Test Result	Net Volume Change	LD Model	3 GPH Simulated Leak Test Result
Regular	Pressurized	Flexible	Pass	+0.0000 gph	FX1V	Pass
Mid-Grade	Pressurized	Flexible	Pass	+0.0000 gph	FX1V	Pass
Premium	Pressurized	Flexible	Pass	+0.0000 gph	FX1V	Pass
Kerosene	Safe Suction	Flexible			N/A	

Comments

Equipment Utilized	Equipment Detail and Certifications
Petro-Tite Line Tester	WI ILHR Material Approval No. - 2007002

Technician Information		
Rod Botero		

Respectfully submitted,