

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

APR 10. 2024 5:33 PM

CSLD TEST RESULTS

APR 10. 2024 5:33 PM

T 1:UNL
PROBE SERIAL NUM 363159

0.2 GAL/HR TEST
PER: APR 10. 2024 PASS

T 2:PLUS
PROBE SERIAL NUM 363200

0.2 GAL/HR TEST
PER: APR 10. 2024 PASS

T 3:PREMIUM
PROBE SERIAL NUM 366409

0.2 GAL/HR TEST
PER: APR 10. 2024 PASS

T 4:KEROSENE
PROBE SERIAL NUM 364080

0.2 GAL/HR TEST
PER: APR 10. 2024 PASS

* * * * * END * * * * *