

001
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (RID) # 2807

Contact Number

Facility Name

Contact email

Address 4023 W Sample St, South Bend, IN 46619

Date of Inspection 09/02/24

Operator on Duty Name

Name of the Person Conducting Inspection AKSHIT

Operator Training current

Operator Training

☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form

☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Release Detection Method

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Release Detection

☒ ATG ☐ TIM ☐ SIR ☐ IC ☐ Other

Spill Buckets

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?
Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☐ Yes ☒ No ☐ Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

Date