

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2807

Contact Number

Facility Name BP

Contact email

Address 4023 W Sample St, South Bend, IN 46619

Date of Inspection 07/15/24

Operator on Duty Name

Name of the Person Conducting Inspection AKS MIT SARRAH

Operator Training current

Operator Training

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form

☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection

☒ ATG ☐ TIM ☐ SIR ☐ IIC ☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?
Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No Operator Notified ☒ Yes ☐ No
☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Piping/STP Sumps

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Contaminants (UDC)

☐ Yes ☒ No Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com