

30 DAYS WALK THROUGH INSPECTION

Oil
Tanks Data

UST Facility I.D. (FID) # 2807 Contact Number

Facility Name BP Contact email

Address 4023 W Sample St, South Bend, IN 46619 Date of Inspection 08/03/24

Operator on Duty Name Name of the Person Conducting Inspection AKSHIT SAKHAR

Operator Training current

Operator Training ☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Is Registration current with correct owner, operator etc. Registration/Notification Form ☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection ☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal
Necessary Monthly Printout Taken

Spill Buckets

☒ Yes ☐ No Operator Notified ☒ Yes ☐ No
☒ Yes ☐ No Operator Notified ☒ Yes ☐ No
☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No Operator Notified ☒ Yes ☐ No
☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports

☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Piping/STP Sumps

☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Containments (UDC) ☐ Yes ☒ No Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com