

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

JUL 15, 2024 2:21 PM

CSLD TEST RESULTS
JUL 15, 2024 2:21 PM

T 1:UNL
PROBE SERIAL NUM 363159
0.2 GAL/HR TEST
PER: JUL 15, 2024 PASS

T 2:PLUS
PROBE SERIAL NUM 363200
0.2 GAL/HR TEST
PER: JUL 15, 2024 PASS

T 3:PREMIUM
PROBE SERIAL NUM 366409
0.2 GAL/HR TEST
PER: JUL 15, 2024 PASS

T 4:KEROSENE
PROBE SERIAL NUM 364080
0.2 GAL/HR TEST
PER: JUL 15, 2024 PASS

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

JUL 15, 2024 2:21 PM

LEAK TEST REPORT

T 1:UNL
PROBE SERIAL NUM 363159

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

JUL 15, 2024 2:21 PM

LEAK TEST REPORT

T 2:PLUS
PROBE SERIAL NUM 363200

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

JUL 15, 2024 2:21 PM

LEAK TEST REPORT

T 3:PREMIUM
PROBE SERIAL NUM 366409

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

JUL 15, 2024 2:21 PM

LEAK TEST REPORT

T 4:KEROSENE
PROBE SERIAL NUM 364080

NO TEST DATA AVAILABLE

***** END *****