

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619
OCT 12, 2025 6:13 PM
OLD TEST RESULTS
OCT 12, 2025 6:13 PM
T 1:UNL
PROBE SERIAL NUM 363159
0.2 GAL/HR TEST
PER: OCT 12, 2025 PASS
T 2:PLUS
PROBE SERIAL NUM 363200
0.2 GAL/HR TEST
PER: OCT 12, 2025 PASS
T 3:PREMIUM
PROBE SERIAL NUM 366409
0.2 GAL/HR TEST
PER: OCT 12, 2025 PASS
T 4:KEROSENE
PROBE SERIAL NUM 364080
0.2 GAL/HR TEST
PER: OCT 12, 2025 PASS
***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619
OCT 12, 2025 6:13 PM
LEAK TEST REPORT
T 1:UNL
PROBE SERIAL NUM 363159
NO TEST DATA AVAILABLE
***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619
OCT 12, 2025 6:13 PM
LEAK TEST REPORT
T 2:PLUS
PROBE SERIAL NUM 363200
NO TEST DATA AVAILABLE
***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619
OCT 12, 2025 6:13 PM
LEAK TEST REPORT
T 3:PREMIUM
PROBE SERIAL NUM 366409
NO TEST DATA AVAILABLE
***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619
OCT 12, 2025 6:13 PM
LEAK TEST REPORT
T 4:KEROSENE
PROBE SERIAL NUM 364080
NO TEST DATA AVAILABLE
***** END *****