

UST Facility I.D. (FID) # <u>2807</u>		Contact Number
Facility Name <u>BP</u>		Contact email
Address <u>4023 N. Sample St, South Bend</u>		Date of Inspection <u>05-12-25</u>
Operator on Duty Name <u>JN-46619</u>		Name of the Person Conducting Inspection <u>Mehon Singh</u>
Operator Training		
☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Registration/Notification Form		
☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Release Detection		
☐ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other		
Make and Model <u>VR-TLS35b</u>		
Does it have paper? ☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Is it in Alarm mode? ☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Interstitial Monitoring Sensor Status Normal		
Necessary Monthly Printout Taken ☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Are Spill Buckets Clean and free from water, debris, product etc? ☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Are the Spill Bucket in good condition and free of damage/cracks ☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Is Fill pipe cap tight and fill pipe free from any obstruction? ☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Are Sumps Clean and free from water, debris, product etc? ☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Piping/STP Sumps		
☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Under Dispenser Containments (UDC)		
Are UDCs clean and free from water, debris, product etc? ☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.		
Operator on Duty Name		Signature
317-645-0215		Date
tanksdata@gmail.com		www.tanksdata.com