

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

FEB 27, 2025 8:07 PM

CSLD TEST RESULTS

FEB 27, 2025 8:07 PM

T 1:UNL

PROBE SERIAL NUM 363159

0.2 GAL/HR TEST

PER: FEB 27, 2025 PASS

T 2:PLUS

PROBE SERIAL NUM 363200

0.2 GAL/HR TEST

PER: FEB 27, 2025 PASS

T 3:PREMIUM

PROBE SERIAL NUM 366409

0.2 GAL/HR TEST

PER: FEB 27, 2025 PASS

T 4:KEROSENE

PROBE SERIAL NUM 364080

0.2 GAL/HR TEST

PER: FEB 27, 2025 PASS

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

FEB 27, 2025 8:07 PM

LEAK TEST REPORT

T 1:UNL

PROBE SERIAL NUM 363159

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

FEB 27, 2025 8:07 PM

LEAK TEST REPORT

T 2:PLUS

PROBE SERIAL NUM 363200

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

FEB 27, 2025 8:07 PM

LEAK TEST REPORT

T 3:PREMIUM

PROBE SERIAL NUM 366409

NO TEST DATA AVAILABLE

***** END *****

872051 SAMPLE ST
4023 W SAMPLE
SOUTH BEND, IN 46619

FEB 27, 2025 8:07 PM

LEAK TEST REPORT

T 4:KEROSENE

PROBE SERIAL NUM 364080

NO TEST DATA AVAILABLE

***** END *****