

THE LANDING
8095 W.US 20
SHIPSHEWANA IN.
46565

MAY 15. 2023 12:00 PM

CSLD TEST RESULTS

MAY 15. 2023 12:00 PM

T 1:UNLEADED
PROBE SERIAL NUM 295152

0.2 GAL/HR TEST
PER: MAY 15. 2023 PASS

T 2:PREMIUM OLD MID
PROBE SERIAL NUM 295151

0.2 GAL/HR TEST
PER: MAY 15. 2023 PASS

T 4:KEROSENE
PROBE SERIAL NUM 295153

0.2 GAL/HR TEST
PER: MAY 15. 2023 PASS

T 5:DIESEL
PROBE SERIAL NUM 295149

0.2 GAL/HR TEST
PER: MAY 15. 2023 PASS

***** END *****

THE LANDING
8095 W.US 20
SHIPSHEWANA IN.
46565

MAY 15. 2023 12:00 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 295152

TEST STARTING TIME:
APR 13. 2016 1:00 AM

HEIGHT = 41.3 INCHES
WATER = 0.0 INCHES
TEMP = 45.5 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4155.5 GAL
PERCENT VOLUME = 41.6

LEAK TEST RESULTS
RATE = 0.07 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

THE LANDING
8095 W.US 20
SHIPSHEWANA IN.
46565

MAY 15. 2023 12:00 PM

LEAK TEST REPORT

T 2:PREMIUM OLD MID