

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE: THE LANDING BP
ADDRESS: 8095 US 20
CITY,ST,ZIP: SHIPSHEWANA, IN 46565

DATE: 11/1/2022

ATG FUNCTIONALITY

ATG MAKE AND MODEL

TANK NUMBER

PRODUCT

TANK VOLUME

TANK DIAMETER

TANK PROBE HAS NO DAMAGED PARTS?

DAMAGED OR MISSING PARTS REPLACED?

FLOATS MOVE FREELY ON STEM?

FUEL FLOAT AGREES W/ CONSOLE?

INCH LEVEL WATER FLOAT ACTIVATES ALARM?

WATER FLOAT AGREES W/ CONSOLE?

INCH LEVEL OVERFILL ACTIVATES ALARM?

OVERFILL ALARM AGREES W/ CONSOLE?

ALL SENSORS LABELED CORRECTLY?

STP/UDC SENSORS ACTIVATE ALARM?

INTERSTITIAL TANK SENSORS ACTIVATE ALARM?

.2 MONTHLY MONITORING ACTIVE?

BATTERY BACKUP IS FUNCTIONAL?

RESULT

COMMENTS:

VR 350

1	2	3	4	5
UNL	PREM		KERO	DSL
10000	6000		4000	12000
96	96		96	96
N	N		N	N
NA	NA		N	N
Y	Y		Y	Y
Y	Y		Y	Y
2	2		2	2
Y	Y			
76	76		77	58
Y	Y		Y	Y
NA	NA		NA	NA
NA	NA		NA	NA
NA	NA		NA	NA
Y	Y		Y	Y
YES				
PASS	PASS		PASS	PASS

TECHNICIAN: RONNIE BROWN

CERTIFICATION:

UC2017IN12086