

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE NAME: THE LANDING BP
STREET NAME: 8095 US 20
CITY,STATE,ZIP: SHIPSHEWANA, IN 46565
DATE: 11/1/2022 TIME: 11:45A

LINE AND LEAK DETECTOR TEST

PRODUCT	UNL	PREM	DSL	KERO	5
OPERATING SYSTEM	PR	PR	PR	PR	
STP MODEL	RJ	RJ	RJ	RJ	
OPERATING PRESSURE	30	30	30	30	
TEST PRESSURE	50	50	50	50	
ISOLATION	CV	CV	CV	SB	
LINE MATERIAL	FG	FG	FG	FG	
BEGINNING LEVEL	0.0300	0.0300	0.0425	0.0670	
10 MIN	0.0300	0.0300	0.0425	0.0670	
20 MIN	0.0300	0.0300	0.0425	0.0670	
30 MIN	0.0300	0.0300	0.0425	0.0670	
AMOUNT OF CHANGE	0.0000	0.0000	0.0000	0.0000	
RESULT	PASS	PASS	PASS	PASS	
LEAK DETECTOR MODEL	FE	VMI	FE	VMI	
LEAK DETECTOR MAKE	MLD	LD2000	MLDD	LD2000	
OPENING TIME	2	2	2	2	
PAUSE PRESSURE	18	22	16	28	
HOLDING PRESSURE	15	15	15	15	
TYPE OF TEST	3GAL/HR	3GAL/HR	3GAL/HR	3GAL/HR	
RESULT	PASS	PASS	PASS	PASS	

COMMENTS

TECHNICIAN

RONNIE BROWN

CERTIFICATION

UC2017IN12086