



Midwest Tank Testing
AN ENVIRONMENTAL COMPLIANCE COMPANY
316 W Indiana Ave.
Chesterton, IN 46304

SPILL BUCKET
(HSB) INTEGRITY TEST
DATA SHEET

DATE AND TIME		9-8-21	8:00-11:45
WEATHER		72 SUNNY	
COLLECT/INVOICE		COLLECTED	
CLIENT E-MAIL			
Testing Company Information			
Name		Midwest Tank Testing	
Address		316 W Indiana Ave.	
City/State/Zip		Chesterton, IN 46304	
Phone		800-975-1436	
Technician Information			
Name		Ryan Hartman	
Cert #		02-6669	

Test Location Information

PC # and WO #	
Name and FID #	BP #18719
Address	8095 W US 20
City/State/Zip	SHIPSHEWANA, IN 46565
Contact	
Phone	574-532-7858

SPILL BUCKET (HSB) INTEGRITY TESTING - HYDROSTATIC METHOD, SINGLE- & DOUBLE-WALLED VACUUM METHOD

This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method, Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.

Tank #	1	2	3	4	5			
Product Stored	REGULAR	PREMIUM	REGULAR 2	KERO	DIESEL			
Spill Bucket Capacity								
Manufacturer	EBW	EBW	EBW	UNIVERSAL	EBW			
Construction (Single-walled/Double-walled)	SW	SW	SW	SW	SW			
Test Type (Hydrostatic/Vacuum) (Single-walled/Double-walled)	HYDRO SW	HYDRO SW	HYDRO SW	HYDRO SW	HYDRO SW			
Spill Bucket Type (Product/Vapor)	Product	Product	Product	Product	Product			
Liquid and Debris Removed From Spill Bucket? (All liquids & debris must be disposed of properly) (Yes/No)	Yes	Yes	Yes	Yes	Yes			
Visual Inspection (No cracks, loose parts or separation of bucket from the fill pipe) If fail, omit test. (Pass/Fail)	Pass	Pass	Pass	Pass	Pass			
Tank Riser Cap Included In Test? (Yes, No, N/A)	Yes	Yes	Yes	Yes	Yes			
Drain Valve Included In Test? (Yes, No, N/A)	Yes	Yes	Yes	Yes	Yes			
Starting Level (inches)	10	10	10	12	10			
Test Start Time	8:50 AM	8:50 AM	8:50 AM	8:50 AM	11:04 AM			
Ending Level (inches)	0	0	0	12	0			
Test End Time	9:50 AM	9:50 AM	9:50 AM	9:50 AM	11:30 AM			
Test Period (minutes)	60	60	60	60	26			
Level Change (inches)	10	10	10	0	10			
Pass/Fail Criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8"; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled: Maintain at least 12 inches water column.								
Test Results (Pass/Fail)	FAIL	FAIL	FAIL	Pass	FAIL			
Comments:								

REVISION 1/21/2020