

THE LANDING  
8095 W.US 20  
SHIPSHEWANA IN.  
46565

SEP 16. 2024 5:48 PM

CSLD TEST RESULTS

SEP 16. 2024 5:48 PM

T 1:UNLEADED  
PROBE SERIAL NUM 295152

0.2 GAL/HR TEST  
PER: SEP 16. 2024 PASS

T 2:PREMIUM OLD MID  
PROBE SERIAL NUM 295151

0.2 GAL/HR TEST  
PER: SEP 16. 2024 PASS

T 4:KEROSENE  
PROBE SERIAL NUM 295153

0.2 GAL/HR TEST  
PER: SEP 16. 2024 PASS

T 5:DIESEL  
PROBE SERIAL NUM 295149

0.2 GAL/HR TEST  
PER: SEP 16. 2024 PASS

\*\*\*\*\* END \*\*\*\*\*

THE LANDING  
8095 W.US 20  
SHIPSHEWANA IN.  
46565

SEP 16. 2024 5:49 PM

LEAK TEST REPORT

T 1:UNLEADED  
PROBE SERIAL NUM 295152

TEST STARTING TIME:  
APR 13. 2016 1:00 AM

HEIGHT = 41.3 INCHES  
WATER = 0.0 INCHES  
TEMP = 45.5 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 4155.5 GAL  
PERCENT VOLUME = 41.6

LEAK TEST RESULTS  
RATE = 0.07 GAL/HR  
THRS = -0.13 GAL/HR  
0.20 GAL/HR TEST PASS

\*\*\*\*\* END \*\*\*\*\*

THE LANDING  
8095 W.US 20  
SHIPSHEWANA IN.  
46565

SEP 16. 2024 5:49 PM

LEAK TEST REPORT

T 2:PREMIUM OLD MID  
PROBE SERIAL NUM 295151

TEST STARTING TIME:  
MAR 27. 2016 12:05 AM

HEIGHT = 18.3 INCHES  
WATER = 0.7 INCHES  
TEMP = 48.0 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 802.3 GAL  
PERCENT VOLUME = 13.4

LEAK TEST RESULTS  
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:  
LOW LEVEL TEST ERROR

\* \* \* \* \* END \* \* \* \* \*

THE LANDING  
8095 W.US 20  
SHIPSEWANA IN.  
46565

SEP 16. 2024 5:49 PM

LEAK TEST REPORT

T 4:KEROSENE  
PROBE SERIAL NUM 295153

TEST STARTING TIME:  
APR 13. 2016 1:00 AM

HEIGHT = 32.0 INCHES  
WATER = 0.9 INCHES  
TEMP = 49.1 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 1172.4 GAL  
PERCENT VOLUME = 29.3

LEAK TEST RESULTS  
RATE = 0.00 GAL/HR  
THRS = -0.13 GAL/HR  
0.20 GAL/HR TEST PASS

\* \* \* \* \* END \* \* \* \* \*

THE LANDING  
8095 W.US 20  
SHIPSEWANA IN.  
46565

SEP 16. 2024 5:49 PM

LEAK TEST REPORT

T 5:DIESEL  
PROBE SERIAL NUM 295149

TEST STARTING TIME:  
FEB 22. 2015 12:05 AM

HEIGHT = 29.9 INCHES  
WATER = 0.0 INCHES  
TEMP = 35.9 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 3221.9 GAL  
PERCENT VOLUME = 26.8

LEAK TEST RESULTS  
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:  
LOW LEVEL TEST ERROR  
TEMP CHANGE TOO LARGE

\* \* \* \* \* END \* \* \* \* \*