

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (RID) # 18719

Facility Name BP

Address 8095 W State Road 201

Operator on Duty Name

Shipshears, Jr. 46565

Contact Number

Contact email

Date of Inspection 10/24/24

Name of the Person Conducting Inspection AKSMT

Operator Training current

Operator Training

☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form

☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection

☒ MFG ☐ CIM ☐ SIR ☐ OC ☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Spill Buckets

☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No Operator Notified ☒ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Pipeline/STP Sumps ☐ Yes ☒ No Operator Notified ☒ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Containments (UDC) ☐ Yes ☒ No Operator Notified ☒ Yes ☐ No

Operator on Duty Name

317-645-0215

Signature

Date

www.tanksdata.com