

UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: Tanks Data
 OWNER ADDRESS: 8095 W State Road 20
 OWNER CITY/STATE/ZIP: Shipshewana, IN 46565

LOCATION NAME: The Landing
 LOCATION ADDRESS: 8095 W State Road 20
 LOCATION CITY/STATE: Shipshewana, IN 46565
 LOCATION FID#: 18719

TESTING DATE: 10/9/2023

METHOD OF TANK LEAK DETECTION -
 METHOD OF PIPING LEAK DETECTION -
 TYPE OF UNDERGROUND PIPING -

ANNUAL TESTING/INSPECTIONS

AUTOMATIC TANK GAUGE TEST

NOT PERFORMED

TANK NO	PRODUCT	BRAND/MODEL	RESULT

PRODUCT LINE TEST

COMPLETED

Product line must be within manufacturer's criteria of +/- .050 GPH.

LINE NO	PRODUCT	RESULT	AMT OF CHG/GPH
1	RUL	PASS	-0.0444
2	PUL	PASS	-0.0148
4	KER	PASS	-0.0296
5	DSL	PASS	-0.0148

LEAK DETECTOR TEST

COMPLETED

LINE NO	PRODUCT	TYPE	RESULT
1	RUL	MLLD	PASS
2	PUL	MLLD	PASS
4	KER	MLLD	UNTESTABLE
5	DSL	0	PASS

LIQUID SENSOR FUNCTIONALITY TEST

NOT PERFORMED

LOCATION	PRODUCT	TYPE	RESULT

LEGEND:

RUL	Regular Unleaded
DSL	Diesel
PUL	Premium Unleaded
KER	Kerosene
ODSL	Off Road Diesel
REC	Recreational

RECOMMENDATIONS:



CERTIFICATION VERIFICATION


Tanks Data
8095 W State Road 20
Shipshewana, IN 46565

Testing Date: 10/9/2023
The Landing
Location of Test: 8095 W State Road 20
Shipshewana, IN 46565
Site FID#: 18719
Service Technician: 0
Certified Technician: PATRICK FOLEY

Midwest ECS has completed the following tests/inspections at the above noted location:

ATG Functionality	
Leak Detector	X
Elec Line Leak Detector	
Product Line Testing	X
Liquid Sensor Functionality	
Spill Bucket	
Containment Hydrostatic Sump	
Overfill Equipment Inspection	
Overfill Alarm	
Vent Valve	
Interstitial	
Non-Volumetric Tank Tightness	
Shear Valve Inspection	

I, PATRICK FOLEY, the certified technician, was present throughout the duration of the testing and/or inspection performed by Midwest ECS at the above address on the above date. I affirm that the testing was done in accordance with Rule 329 IAC 9 and 40CFR Part 80, is accurate based upon the results received and that these forms accurately reflects the results of the testing and/or inspection.

Technician Signature: 
Technician Printed Name: PATRICK FOLEY
Date & Time: 10/9/2023 5:22

				INDIANA HOMELAND SECURITY		
				Underground Storage Tank		
				PATRICK FOLEY 602 S 21ST STREET LAFAYETTE, INDIANA		
STATE/PERMIT #	ISSUE	EFFECTIVE	EXPIRATION			
UC111246	09/15/2022	09/16/2022	09/15/2024			
DISCIPLINES						
☒ Installation or Retrofitting			☐ Decommissioning Closure			
☐ Cathodic Protection			☐ Decommissioning Removal			

I attest with my signature below, that this technician was present onsite for testing as described above.

