

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE NAME: MARATHON FID 25131
STREET NAME: 1149 N MAIN ST
CITY,STATE,ZIP: GOSHEN, IN 46528
DATE: 2/1/2023 TIME: 10:00A

LINE AND LEAK DETECTOR TEST

PRODUCT	UNL	PREM	DSL	4	5
OPERATING SYSTEM	PR	PR	PR		
STP MODEL	FE	FE	FE		
OPERATING PRESSURE	32	32	32		
TEST PRESSURE	50	50	50		
ISOLATION	BV	CV	BV		
LINE MATERIAL	FLEX	FLEX	FLEX		
BEGINNING LEVEL	0.0670	0.0550	0.0300		
10 MIN	0.0670	0.0550	0.0300		
20 MIN	0.0670	0.0550	0.0300		
30 MIN	0.0670	0.0550	0.0300		
AMOUNT OF CHANGE	0.0000	0.0000	0.0000		
RESULT	PASS	PASS	PASS		
LEAK DETECTOR MODEL	VMI	VMI	FE		
LEAK DETECTOR MAKE	LD2000	LD2000	MLD		
OPENING TIME	2	2	2		
PAUSE PRESSURE	22	22	18		
HOLDING PRESSURE	25	25	22		
TYPE OF TEST	3GAL/HR	3GAL/HR	3GAL/HR		
RESULT	PASS	PASS	PASS		

COMMENTS

TECHNICIAN RONNIE BROWN CERTIFICATION UC2017IN12086