

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE: MARATHON
ADDRESS: 1149 N MAIN ST
CITY,ST,ZIP: GOSHEN, IN 46528

FID 25131

DATE: 2/1/2023

ATG FUNCTIONALITY

ATG MAKE AND MODEL

TANK NUMBER

PRODUCT

TANK VOLUME

TANK DIAMETER

TANK PROBE HAS NO DAMAGED PARTS?

DAMAGED OR MISSING PARTS REPLACED?

FLOATS MOVE FREELY ON STEM?

FUEL FLOAT AGREES W/ CONSOLE?

INCH LEVEL WATER FLOAT ACTIVATES ALARM?

WATER FLOAT AGREES W/ CONSOLE?

INCH LEVEL OVERFILL ACTIVATES ALARM?

OVERFILL ALARM AGREES W/ CONSOLE?

ALL SENSORS LABELED CORRECTLY?

STP/UDC SENSORS ACTIVATE ALARM?

INTERSTITIAL TANK SENSORS ACTIVATE ALARM?

.2 MONTHLY MONITORING ACTIVE?

BATTERY BACKUP IS FUNCTIONAL?

RESULT

COMMENTS:

OVERFILL IS SET BEYOND PARAMETERS OF TANK DIAMETER.

INCON 750

1	2	3	4	5
UNL	PREM	DSL		
15236	7916	7950		
119	125	92		
N	N	N		
NA	NA	NA		
Y	Y	Y		
Y	Y	Y		
2	2	2		
Y	Y	Y		
120	120	101		
NA	NA	NA		
NA	NA	NA		
NA	NA	NA		
NA	NA	NA		
Y	Y	Y		
YES				
PASS	PASS	PASS		

TECHNICIAN: RONNIE BROWN

CERTIFICATION:

UC2017IN12086