

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility ID (FID) # 25131	Contact Number	779-801-2380	
Facility Name Marathon	Contact email		
Address 1149 N. Main St. Goshen 46528	Date of Inspection	7/13/22	
Operator on Duty Name Mandeep	Name of the Person Conducting Inspection	Josh Rider	
Operator Training			
Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Registration/Notification Form			
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection			
Release Detection Method	☒ ATG ☒ CIM ☐ SIR ☐ LC ☐ Other		
Make and Model	Incon TS-750		
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Fill Ports			
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Piping/STP Sumps			
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
NOTE: ALL LIQUID DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name	Signature	Date	7/13/22
317-645-0215	tanksdata@gmail.com	www.tanksdata.com	

20220516

NORTH MEADOW C-STOR
1149 N. MAIN ST.
GOSHEN, IN 46528
574-975-0391

07/13/2022 2:17 PM

SPALD TEST REPORT

TANK 1 15236.8 GAL
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALITY 0.02
TEST STARTED 6:51 PM
TEST STARTED 07/05/2022
STATUS 0.02
TEST ENDED 11:11 PM
TEST ENDED 07/10/2022

SLOPE -0.007 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

TANK 2 7917.8 GAL
PREM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALITY 0.02
TEST STARTED 4:11 AM
TEST STARTED 07/13/2022
STATUS 0.02
TEST ENDED 7:49 AM
TEST ENDED 07/13/2022

SLOPE -0.042 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

TANK 3 7950.8 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALITY 0.02
TEST STARTED 8:24 AM
TEST STARTED 07/13/2022
STATUS 0.02
TEST ENDED 11:13 AM
TEST ENDED 07/13/2022

SLOPE 0.015 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE