

WORTH HEADQUARTERS
1145 N. MAIN ST.
DOWEN IN 45628
974-975-6791

05/15/2023 11:40 PM

LEAK TEST REPORT

TANK 1 15736.0 GAL
UNLEAD

LEAK TEST 0.200 GPM
LEAK THRESHOLD 0.100 GPM
INTERVAL 15.0
IGN FUEL TEST 0.00
TEST STARTED 11:17 PM
TEST STARTED 05/11/2023
STATUS 3000.00
TEST FINISH 11:40 PM
TEST FINISH 05/12/2023

0.000 0.000 GAL/HOUR
TEST RESULT PASSED
0.000 FUELS CALCULATED
LEAK RATE

TANK 2 2917.0 GAL
DIESEL

LEAK TEST 0.200 GPM
LEAK THRESHOLD 0.100 GPM
INTERVAL 15.0
IGN FUEL TEST 0.00
TEST STARTED 05/15/2023
STATUS 1100.00
TEST FINISH 05/15/2023

0.000 -0.041 GAL/HOUR
TEST RESULT PASSED
0.000 FUELS CALCULATED
LEAK RATE

TANK 3 7950.0 GAL
DIESEL

LEAK TEST 0.200 GPM
LEAK THRESHOLD 0.100 GPM
INTERVAL 15.0
IGN FUEL TEST 0.00
TEST STARTED 05/15/2023
STATUS 0.00
TEST FINISH 05/15/2023

0.000 -0.015 GAL/HOUR
TEST RESULT PASSED
0.000 FUELS CALCULATED
LEAK RATE

WORTH HEADQUARTERS
1145 N. MAIN ST.
DOWEN IN 45628
974-975-6791

05/15/2023 11:40 PM

LEAK ESTIMATE REPORT

TANK 1

LEAK TEST 0.200 GPM
CONCENTRATION (LUE) 99.00
GROSS CAPACITY 25.00
GROSS 3458.2 GAL
NET 3458.2 GAL
LUE 33.930 IN
TEMP 55.062 F
WATER IN 0.0 GAL
WATER LUE 0.008 IN
EST TIME 5 HRS 30 MIN

TANK 2

LEAK TEST 0.200 GPM
CONCENTRATION (LUE) 99.00
GROSS CAPACITY 25.00
GROSS 2046.7 GAL
NET 2047.5 GAL
LUE 33.930 IN
TEMP 54.296 F
WATER IN 0.1 GAL
WATER LUE 0.006 IN
EST TIME 2 HRS 40 MIN

TANK 3

LEAK TEST 0.200 GPM
CONCENTRATION (LUE) 99.00
GROSS CAPACITY 25.00
GROSS 2049.7 GAL
NET 2049.8 GAL
LUE 33.930 IN
TEMP 54.337 F
WATER IN 0.1 GAL
WATER LUE 0.012 IN
EST TIME 3 HRS 55 MIN

WORTH HEADQUARTERS
1145 N. MAIN ST.
DOWEN IN 45628
974-975-6791

05/15/2023 11:41 PM

LEAK TEST REPORT

TANK 1 15736.0 GAL
UNLEAD

LEAK TEST 0.200 GPM
LEAK THRESHOLD 0.100 GPM
CONCENTRATION (LUE) 99.00
TEST STARTED 12:18 AM
TEST STARTED 05/05/2019
FACT DELIVERY 01:08 AM
FACT DELIVERY 05/07/2019
GROSS CAPACITY 56.00
GROSS NET 8511.6 GAL
GROSS LUE 65.094 IN
GROSS TEMP 66.386 F
GROSS WATER 0.0 GAL
GROSS WATER 0.006 IN
END TIME 01:09 AM
END DATE 05/08/2019
END GROSS 8514.3 GAL
END NET 8495.0 GAL
END LUE 65.090 IN
END TEMP 66.337 F
END WATER 0.0 GAL
END WATER 0.005 IN

HOURLY DATA

TIME DEG F GAL
1100 AM 66.730 8495.73
1100 AM 66.376 8495.44
1100 AM 66.417 8495.33
1100 AM 66.456 8495.05
1100 AM 66.490 8494.88
1100 AM 66.525 8495.11

0.000 -0.145 GAL/HOUR
0.000 LUE -0.147 GAL/HOUR
0.000 LUE -0.147 GAL/HOUR
TEST RESULT FAILED
0.000 FUELS CALCULATED
LEAK RATE