

NORTH MEADOW C-STOR
1149 N. MAIN ST.
GSHEN IN 45628
574-975-0391

01/25/2024

3:06 PM

SEALD TEST REPORT

TANK 1 15236.0 GAL.
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UNL QUALIFY 0.02
TEST STARTED 2:17 AM
TEST STARTED 01/12/2024
STATUS 0.02
TEST ENDED 7:22 AM
TEST ENDED 01/24/2024

SLOPE -0.029 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

TANK 2 7917.0 GAL
PREM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UNL QUALIFY 0.02
TEST STARTED 5:36 AM
TEST STARTED 01/24/2024
STATUS 1000.02
TEST ENDED 12:11 PM
TEST ENDED 01/24/2024

SLOPE -0.048 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

TANK 3 7950.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UNL QUALIFY 0.02
TEST STARTED 10:44 AM
TEST STARTED 01/25/2024
STATUS 0.02
TEST ENDED 12:50 PM
TEST ENDED 01/25/2024

SLOPE -0.013 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

NORTH MEADOW C-STOR
1149 N. MAIN ST.
GSHEN IN 45628
574-975-0391

01/25/2024

3:07 PM

LEAK TEST REPORT

TANK 1 15236.0 GAL.
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE (FUEL) 99.02
TEST STARTED 12:10 AM
TEST STARTED 09/08/2019
LAST DELIVERY 01:28 AM
LAST DELIVERY 09/07/2019
GROSS CAPACITY 56.002
BEGIN GROSS 8533.6 GAL
BEGIN NET 8495.0 GAL
BEGIN FUEL 65.094 IN
BEGIN TEMP 66.306 F
BEGIN WATER 0.0 GAL
BEGIN WATER 0.036 IN
END TIME 01:29 AM
END DATE 09/08/2019
END GROSS 8534.3 GAL
END NET 8495.0 GAL
END FUEL 65.090 IN
END TEMP 66.537 F
END WATER 0.0 GAL
END WATER 0.035 IN

HOURLY DATA

TIME DEG F GAL
1:00 AM 66.330 8495.73

(INL-PR)

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 99.0%
TEST STARTED 09/08/2019 12:18 AM
TEST DELIVERY 09/08/2019 9:28 AM
CONDS CAPACITY 56.8%
DETN GROSS 8495.6 GAL
DETN NET 8495.8 GAL
DETN LEVEL 65.894 IN
DETN TEMP 66.306 F
DETN WATER 0.0 GAL
DETN WATER 0.036 IN
END TIME 6:20 AM
END DATE 09/08/2019
END GROSS 8496.3 GAL
END NET 8495.8 GAL
END LEVEL 65.890 IN
END TEMP 66.537 F
END WATER 0.0 GAL
END WATER 0.035 IN

HOURLY DATA

TIME DEG F GAL
1:00 AM 66.338 8495.73
2:00 AM 66.376 8495.44
3:00 AM 66.413 8495.33
4:00 AM 66.454 8495.05
5:00 AM 66.490 8494.98
6:00 AM 66.525 8495.11

CLDR -0.145 GAL/HR
CLDR LOW -0.147 GAL/HR
CLDR HIGH -0.143 GAL/HR
TEST RESULT FAILED
CLDR EQUALS CALCULATED
LEAK RATE

TANK 2 7917.0 GAL

PREM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 99.0%
TEST STARTED 09/08/2019 12:18 AM
TEST DELIVERY 09/08/2019 9:27 AM
CONDS CAPACITY 22.2%
DETN GROSS 1758.8 GAL
DETN NET 1751.6 GAL
DETN LEVEL 34.926 IN
DETN TEMP 66.533 F
DETN WATER 0.0 GAL
DETN WATER 0.040 IN
END TIME 2:50 AM
END DATE 09/08/2019
END GROSS 1758.7 GAL
END NET 1751.5 GAL
END LEVEL 34.926 IN
END TEMP 66.582 F
END WATER 0.0 GAL
END WATER 0.041 IN

HOURLY DATA

TIME DEG F GAL
1:00 AM 66.585 1751.76
2:00 AM 66.571 1751.72

CLDR -0.020 GAL/HR
CLDR LOW -0.021 GAL/HR
CLDR HIGH -0.019 GAL/HR
TEST RESULT PASSED
CLDR EQUALS CALCULATED
LEAK RATE

TANK 3 7950.0 GAL

DIFSEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 99.0%
TEST STARTED 09/08/2019 12:18 AM
TEST DELIVERY 09/08/2019 7:48 PM
CONDS CAPACITY 25.9%
DETN GROSS 2062.7 GAL
DETN NET 2052.6 GAL
DETN LEVEL 20.303 IN
DETN TEMP 70.199 F
DETN WATER 0.1 GAL
DETN WATER 0.023 IN
END TIME 4:09 AM
END DATE 09/08/2019
END GROSS 2062.7 GAL
END NET 2052.7 GAL
END LEVEL 20.303 IN
END TEMP 70.146 F
END WATER 0.1 GAL
END WATER 0.023 IN

HOURLY DATA

TIME DEG F GAL
1:00 AM 70.185 2052.65
2:00 AM 70.173 2052.70
3:00 AM 70.160 2052.69
4:00 AM 70.146 2052.78

CLDR 0.000 GAL/HR
CLDR LOW 0.000 GAL/HR
CLDR HIGH 0.010 GAL/HR
TEST RESULT PASSED
CLDR EQUALS CALCULATED
LEAK RATE

NORTH HAVEN C-STOR
1149 N. MAIN ST
NORTH HAVEN, CT 06460
974-975-0191

01/25/2024 3:09 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CTM NOT INSTALLED

TANK 1

7000.0 GAL

DIFSEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE (FUEL) 99.0%
TEST STARTED 09/08/2019 12:18 AM
TEST STOPPED 09/08/2019 7:48 PM
LAST DET. TUEV 09/08/2019
TANK CAPACITY 25.0%
DET. GROSS 2062.7 GAL
DET. NET 2052.6 GAL
DET. FUEL 79.303 IN
DET. TEMP 79.199 F
DET. WATER 0.1 GAL
DET. WATER 0.023 IN
END TIME 4:09 AM
END DATE 09/08/2019
END GROSS 2062.7 GAL
END NET 2052.7 GAL
END FUEL 79.303 IN
END TEMP 79.146 F
END WATER 0.1 GAL
END WATER 0.023 IN

HOURLY DATA

TIME DEG F GAL
1:09 AM 70.185 2052.65
2:09 AM 70.173 2052.70
3:09 AM 70.160 2052.69
4:09 AM 70.146 2052.78

CL. DEF 0.009 GAL/HR
CL. DEF LOW 0.008 GAL/HR
CL. DEF HIGH 0.010 GAL/HR
TEST RESULT PASSED
CL. DEF EQUALS CAL. DILATED
LEAK RATE

NORTH MEADOW C-STOR
1140 N. MAIN ST.
DOVER TN 37030
674-975-0701

01/24/2024 3:09 PM

REGULATORY REPORT

HARDWARE STATUS

TS-PTM NOT INSTALLED
TS-DNM NOT INSTALLED
TS-SFM 1 NOT INSTALLED
TS-SFM 2 NOT INSTALLED
TS-CPM NOT INSTALLED
DOTATED OPERATIONAL
CAY/MND OPERATIONAL

PROBES

PROBE 1 OPERATIONAL
PROBE 2 OPERATIONAL
PROBE 3 OPERATIONAL

ALIM/TADV THIRTS

ALIM IN 1 OPERATIONAL
ALIM IN 2 OPERATIONAL

PASSED LEAK TESTS

TANK 1
02/24/2019 6:09 AM
LEAK TEST 0.20 GPH
CL. DEF -0.02 GPH

TANK 2
09/08/2019 2:50 AM
LEAK TEST 0.20 GPH
CL. DEF -0.02 GPH

TANK 3
09/08/2019 4:09 AM
LEAK TEST 0.20 GPH
CL. DEF 0.01 GPH

PASSED SCALD TESTS

TANK 1
01/24/2024 2:22 AM
LEAK TEST 0.20 GPH
CL. DEF -0.03 GPH

03/30/2031 12:55 AM
LEAK TEST 0.20 GPH
CL. DEF -0.06 GPH

07/28/2031 4:07 AM
LEAK TEST 0.20 GPH
CL. DEF -0.05 GPH

07/03/2021 10:58 PM
LEAK TEST 0.20 GPH
CL. DEF -0.06 GPH

TANK 2
01/24/2024 12:11 PM
LEAK TEST 0.20 GPH
CL. DEF -0.05 GPH

04/18/2031 11:47 AM
LEAK TEST 0.20 GPH
CL. DEF -0.04 GPH

03/18/2031 10:18 PM
LEAK TEST 0.20 GPH
CL. DEF 0.02 GPH

07/17/2031 12:07 AM
LEAK TEST 0.20 GPH
CL. DEF 0.02 GPH

07/16/2021 4:00 AM
LEAK TEST 0.20 GPH
CL. DEF -0.03 GPH

01/24/2024 10:00 AM
LEAK TEST 0.20 GPH
CL. DEF 0.02 GPH