

NORTH MEADOW C-STOR
1149 N. MAIN ST.
OSHEN IN 45628
574-975-8391

07/28/2024 11:31 AM

LEAK TEST REPORT

TANK 1 15236.0 GAL
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 10.0
MIN. QUANTITY 0.00
TEST STARTED 07/26/2024 3:16 AM
TEST STARTED 07/26/2024 0.02
STATUS 3:34 AM
TEST ENDED 07/27/2024

CLONE -0.074 GAL/HR
TEST RESULT PASSED
CLONE EQUALS CALCULATED
LEAK RATE

TANK 2 7917.0 GAL
PREM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 10.0
MIN. QUANTITY 0.00
TEST STARTED 07/27/2024 4:51 PM
TEST STARTED 07/27/2024 0.02
STATUS 10:16 PM
TEST ENDED 07/27/2024

CLONE 0.021 GAL/HR
TEST RESULT PASSED
CLONE EQUALS CALCULATED
LEAK RATE

TANK 3 7950.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 10.0
MIN. QUANTITY 0.00
TEST STARTED 07/28/2024 3:09 AM
TEST STARTED 07/28/2024 0.02
STATUS 5:19 AM
TEST ENDED 07/28/2024

CLONE -0.003 GAL/HR
TEST RESULT PASSED
CLONE EQUALS CALCULATED
LEAK RATE

NORTH MEADOW C-STOR
1149 N. MAIN ST.
OSHEN IN 45628
574-975-8391

07/28/2024 11:32 AM

LEAK TEST REPORT

TANK 1 15236.0 GAL
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 99.00
TEST STARTED 09/02/2019 12:10 AM
TEST STARTED 09/02/2019 9:20 AM
LAST DELIVERY 09/07/2019
GROSS CAPACITY 56.00
BEGIN GROSS 8533.6 GAL
BEGIN NET 8495.0 GAL
BEGIN LEVEL 65.894 IN
BEGIN TEMP 66.386 F
BEGIN WATER 0.0 GAL
BEGIN WATER 0.835 IN
END TIME 6:29 AM
END DATE 09/08/2019
END GROSS 8574.3 GAL
END NET 8495.0 GAL
END LEVEL 65.898 IN
END TEMP 66.537 F
END WATER 0.0 GAL
END WATER 0.835 IN

HOURLY DATA

TIME DEG F GAL
1100 AM 66.330 8495.21
2100 AM 66.376 8495.44
3100 AM 66.415 8495.33
4100 AM 66.456 8495.05
5100 AM 66.490 8494.80
6100 AM 66.525 8495.11

SLOPE -0.145 GAL/HR
SLOPE LOW -0.147 GAL/HR
SLOPE HIGH -0.143 GAL/HR
TEST RESULT FAILED
SLOPE EQUALS CALCULATED
LEAK RATE

TANK 2 7917.0 GAL
PREM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 99.00
TEST STARTED 09/02/2019 12:10 AM
TEST STARTED 09/02/2019 9:27 AM
LAST DELIVERY 09/07/2019
GROSS CAPACITY 22.22
BEGIN GROSS 1768.0 GAL
BEGIN NET 1751.6 GAL
BEGIN LEVEL 34.506 IN
BEGIN TEMP 66.533 F
BEGIN WATER 0.0 GAL
BEGIN WATER 0.844 IN
END TIME 2:50 AM
END DATE 09/08/2019
END GROSS 1768.7 GAL
END NET 1751.5 GAL
END LEVEL 34.506 IN
END TEMP 66.000 F