



Petroleum Construction and Environmental Services Specialists

May 8, 2023

Site: FID# 18872
12530 US Hwy 20
Mishawaka, IN 46545

Re: Piping Verification

This is to certify that Jacobs Professional Services, LLC (JPS) broke concrete excavated and exposed product piping at STP and entry into the middle dispenser sump. Piping was visually verified to be AMERON SINGLE-WALL FIBERGLASS. Additionally, JPS provided photo of piping in previous correspondence with the site Owner.

Feel free to contact our office should you have any questions. Thank you.

Respectfully submitted,

Edward D. Jacobs

Edward D. Jacobs, principal project manager