



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

**UST OVERFILL EQUIPMENT INSPECTION
AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE**

Facility Name:

Address:

City, State, Zip Code:

Facility I.D. #:

Owner:

Address:

City, State, Zip Code:

Phone #:

This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.

Product Grade						
Tank Number						
Tank Volume, gallons						
Tank Diameter, inches						
Overfill Prevention Device Brand						
Type						

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?						
2. Drop tube and float mechanisms free of debris?						
3. Float moves freely without binding and poppet moves into flow path?						
4. Bypass valve in the drop tube open and free of blockage (if present)?						
5. Flapper adjusted to shut off flow at 95% capacity?*						

A "No" to any item in Lines 1-5 indicates a test failure.

BALL FLOAT VALVE INSPECTION

1. Tank top fittings vapor-tight and leak-free?						
2. Ball float cage free of debris?						
3. Ball free of holes and cracks and moves freely in cage?						
4. Vent hole in pipe open and near top of tank?						
5. Ball float pipe proper length to restrict flow at 90% capacity						

A "No" to any item in Lines 1-5 indicates a test failure.

Total Results						
---------------	--	--	--	--	--	--

Comment:

Tester's Name : _____

Tester's Signature : _____