



5296 Breakers Way, Carmel, IN 46033

Date

LIQUID SENSOR FUNCTIONALITY TESTING

Facility Name:

Address:

City, State, Zip Code:

Facility I.D. #:

Owner:

Address:

City, State, Zip Code:

Phone #:

This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PEI/RP1200 Section 8.3 for the test procedure.

Sensor Location							
Product Stored							
Type of Sensor							
Test Liquid							
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor? If the sensor is in alarm and functioning, indicate why.							
Is the sensor alarm circuit operational?							
Has sensor been inspected and in good operating condition?							
When placed in the test liquid, does the sensor trigger an alarm?							
When an alarm is triggered, is the sensor properly identified on the ATG console?							
Any "No" answers indicates the sensor fails the test.							
Test Results							

Comment

Tester's Name : _____

Tester's Signature : _____