



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

HYDROSTATIC SPILL BUCKET INTEGRITY TEST

SINGLE- AND DOUBLE-WALLED VACUUM TEST METHOD

Facility Name:	Owner:
Address:	Address:
City, State, Zip Code:	City, State, Zip Code:
Facility I.D. #:	Phone #:

This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method, Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.

Tank Number						
Product Stored						
Spill Bucket Capacity						
Manufacturer						
Construction						
Test Type						
Spill Bucket Type						
Liquid and debris removed from spill bucket?						
Visual Inspection (No cracks, loose parts or separation of the bucket from the fill pipe.)						
Tank riser cap included in test?						
Drain valve included in test?						
Starting Level						
Test Start Time						
Ending Level						
Test End Time						
Test Period						
Level Change						
Pass/fail criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled: maintain at least 12 inches water column						
Test Results						

Comments:

Tester's Name : _____

Tester's Signature : _____