

010
Tank Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 15500	Contact Number
Facility Name <i>McPherson</i>	Contact email
Address <i>750 CR 15 Elkhart IN 46516</i>	Date of Inspection <i>3-7-24</i>
Operator on Duty Name	Name of the Person Conducting Inspection <i>Austin B.</i>

Operator Training current	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
---------------------------	--------------------------------------	--------------------------	-------------------	---------------------------	--------------------------

Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Registration/Notification Form	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
---	---------------------------	--------------------------	--------------------------------	---------------------------	--------------------------	-------------------	---------------------------	--------------------------

Release Detection Method	☒ ATG	☒ DIM	☐ SIR	☐ IIC	☐ Other
--------------------------	--------------------------------------	--------------------------------------	---------------------------	---------------------------	-----------------------------

Make and Model	<i>VR</i>	<i>TLS 450+</i>	Operator Notified	☐ Yes	☐ No
----------------	-----------	-----------------	-------------------	---------------------------	--------------------------

Does it have paper?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
---------------------	--------------------------------------	--------------------------	-------------------	---------------------------	--------------------------

Is it in Alarm mode?	☐ Yes	☒ No	Operator Notified	☐ Yes	☐ No
----------------------	---------------------------	-------------------------------------	-------------------	---------------------------	--------------------------

Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
--	--------------------------------------	--------------------------	-------------------	---------------------------	--------------------------

Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
----------------------------------	--------------------------------------	--------------------------	-------------------	---------------------------	--------------------------

Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes	☒ No	Operator Notified	☒ Yes	☐ No
---	---------------------------	-------------------------------------	-------------------	--------------------------------------	--------------------------

Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
--	--------------------------------------	--------------------------	-------------------	---------------------------	--------------------------

Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
---	--------------------------------------	--------------------------	-------------------	---------------------------	--------------------------

Are Sumps Clean and free from water, debris, product etc?	☐ Yes	☒ No	Operator Notified	☒ Yes	☐ No
---	---------------------------	-------------------------------------	-------------------	--------------------------------------	--------------------------

Under Dispenser Contaminants (UDC)	☐ Yes	☒ No	Operator Notified	☒ Yes	☐ No
------------------------------------	---------------------------	-------------------------------------	-------------------	--------------------------------------	--------------------------

Are UDCs clean and free from water, debris, product etc?	☐ Yes	☒ No	Operator Notified	☒ Yes	☐ No
--	---------------------------	-------------------------------------	-------------------	--------------------------------------	--------------------------

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
-----------------------	-----------	------