

03/07/24 1:56 PM
Mobil
750 County Road 15
Elkhart In
PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY
Ln 1: Regular Unleaded

Gross Test 119
Prev 24 Hours 67
Since Midnight
Gross 03/07/24 1:53 PM
Periodic 03/07/24 2:29 AM
Annual 03/01/24 11:02 PM
First Periodic 03/01/24 11:02 PM
First Annual 03/01/24 11:02 PM

Ln 2: Premium Unleaded
Gross Test 179
Prev 24 Hours 99
Since Midnight
Gross 03/07/24 1:55 PM
Periodic 03/07/24 3:13 AM
Annual 03/07/24 3:13 AM
First Periodic 03/07/24 3:13 AM

Ln 3: Diesel
Gross Test 21
Prev 24 Hours 13
Since Midnight
Gross 03/07/24 11:58 AM
Periodic 03/07/24 11:52 AM
Annual 03/03/24 6:29 PM
First Periodic 03/03/24 6:29 PM

Ln 4: K-1
Gross Test 0
Prev 24 Hours 0
Since Midnight
Gross 03/01/24 5:22 PM
Periodic 03/01/24 5:57 PM
Annual 03/01/24 6:15 PM
First Periodic 03/01/24 5:57 PM
First Annual 03/01/24 6:15 PM

REI
DA
ME
HDX
AVI
% I

REI
DA
ME
HDX
AVI
% I

03/07/24 1:56 PM
REI
DA Mobil
ME 750 County Road 15
HDX Elkhart In
AVI
% I

Sensor Status Report -
All Sensors
Sensor Location Status
1 Reg NL Stp Sump NORMAL
2 Premium Stp Sump NORMAL
3 Diesel Stp Sump NORMAL
4 K-1 Stp Sump NORMAL
5 NL / Prem Annula NORMAL
6 Diesel/K-1 Annul NORMAL

REI
DA
ME
HDX
AVI
% I

03/07/24 1:56 PM
Mobil
750 County Road 15
Elkhart In

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: Regular Unleaded

REPORT TYPE = LAST GROSS
DATE/TIME = 03/07/24 3:00
METHOD = SLD Gross Test
AVG. VOLUME = 10859
% VOLUME = 54.9
REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/07/24 3:33
METHOD = CSLD Periodic Test
HOURS = 15
AVG. VOLUME = 11690
% VOLUME = 59.1
REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/07/24 3:33
METHOD = CSLD Periodic Test
HOURS = 15
AVG. VOLUME = 11690
% VOLUME = 59.1