

APPENDIX C-4

CONTAINMENT SUMP INTEGRITY TESTING

HYDROSTATIC TESTING METHOD

TEST DATE: 10/10/2023

LOCATION NAME: Punjab Group

LOCATION ADDRESS: 750 County Road 15

LOCATION CITY/STATE: Elkhart, IN 46516

LOCATION PHONE: 0

LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data

OWNER ADDRESS: 750 County Road 15

OWNER CITY/STATE/ZIP: Elkhart, IN 46516

LOCATION FID#: 15500

WORK ORDER NO: NE-0557

This procedure is to test the leak integrity of containment sumps. See PEI/RP1200 Section 6.5 for the test method.

Containment Sump ID	RUL STP	PUL STP	DSL STP	KER STP	DISP 1/2	DISP 3/4
Containment Sump Material	FIBERGLASS	FIBERGLASS	FIBERGLASS	FIBERGLASS	POLY	POLY
Containment Sump Depth	42"	42"	42"	42"	16"	16"
Height From Bottom to Top of Highest Penetration	10"	10"	10"	10"	6"	6"
Starting Water Level	18"	20"	21"	20.75"	10.75"	9.75"
Test Start Time	11:55	11:55	11:55	11:55	12:30	12:30
Ending Water Level	18"	20"	21"	20.75"	10.75"	9.75"
Test End Time	12:55	12:55	12:55	12:55	1:30	1:30
Test Period (Minimum test time: 1 hour)	1HR	1HR	1HR	1HR	1HR	1HR
Water Level Change	0"	0"	0"	0"	0"	0"
2. Ball float cage free of debris?	N/A	N/A	N/A	N/A	N/A	N/A
3. Ball free of holes an cracks and moves freely in cage?	N/A	N/A	N/A	N/A	N/A	N/A
4. Vent hole in pipe open and near top of tank?	N/A	N/A	N/A	N/A	N/A	N/A
HYDROSTATIC TEST RESULTS	PASS	PASS	PASS	PASS	PASS	PASS
VISUAL INSPECTION RESULTS	PASS	PASS	PASS	PASS	PASS	PASS
Liquid and debris removed from sump?*	YES	YES	YES	YES	YES	YES

Visual Inspection Criteria: No cracks, loose parts or separation of the containment sump

Recommended Practices Pass/Fail criteria: Must pass visual inspection. Water level drop of less than 1/8 inch.

COMMENTS:

* All liquids must be disposed of properly.

0

SERVICE TECHNICIAN NAME (printed)

ADAM WILDER

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE



CERTIFIED TECHNICIAN SIGNATURE

CERT NO: 000, U1-UC111458
 EXPIRATION DATE: 8/18/2024, 10/06/

APPENDIX C-4

CONTAINMENT SUMP INTEGRITY TESTING

HYDROSTATIC TESTING METHOD

TEST DATE: 10/10/2023
 LOCATION NAME: Punjab Group
 LOCATION ADDRESS: 750 County Road 15
 LOCATION CITY/STATE: Elkhart, IN 46516
 LOCATION PHONE: 0
 LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data
 OWNER ADDRESS: 750 County Road 15
 OWNER CITY/STATE/ZIP: Elkhart, IN 46516
 LOCATION FID#: 15500
 WORK ORDER NO: NE-0557

This procedure is to test the leak integrity of containment sumps. See PEI/RP1200 Section 6.5 for the test method.

Containment Sump ID	DISP 5/6	DISP 7/8	DISP 9/10	DISP 11/12		
Containment Sump Material	POLY	POLY	POLY	POLY		
Containment Sump Depth	16"	16"	16"	16"		
Height From Bottom to Top of Highest Penetration	6"	6"	6"	6"		
Starting Water Level	10.5"	10"	10.5"	11.75"		
Test Start Time	12:30	12:30	12:30	12:30		
Ending Water Level	10.5"	10"	10.5"	11.75"		
Test End Time	1:30	1:30	1:30	1:30		
Test Period (Minimum test time: 1 hour)	1HR	1HR	1HR	1HR		
Water Level Change	0"	0"	0"	0"		
2. Ball float cage free of debris?	N/A	N/A	N/A	N/A		
3. Ball free of holes an cracks and moves freely in cage?	N/A	N/A	N/A	N/A		
4. Vent hole in pipe open and near top of tank?	N/A	N/A	N/A	N/A		
HYDROSTATIC TEST RESULTS	PASS	PASS	PASS	PASS	-	-
VISUAL INSPECTION RESULTS	PASS	PASS	PASS	PASS	-	-
Liquid and debris removed from sump?*	YES	YES	YES	YES	-	-

Visual Inspection Criteria: No cracks, loose parts or separation of the containment sump

Recommended Practices Pass/Fail criteria: Must pass visual inspection. Water level drop of less than 1/8 inch.

COMMENTS:

* All liquids must be disposed of properly.

0

SERVICE TECHNICIAN NAME (printed)
ADAM WILDER

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE


CERTIFIED TECHNICIAN SIGNATURE

CERT NO: 000, U1-UC111458
 EXPIRATION DATE: 8/18/2024, 10/06/