

05/30/24 4:02 PM

Mobil
750 County Road 15
Elkhart In

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: Regular Unleaded

Gross Test

Prev 24 Hours 117
Since Midnight 82

Last Gross 05/30/24 3:56 PM

Last Periodic 05/27/24 1:06 AM

First Periodic 05/11/24 1:39 AM

Ln 2: Premium Unleaded

Gross Test

Prev 24 Hours 192
Since Midnight 137

Last Gross 05/30/24 3:59 PM

Last Periodic 05/26/24 2:43 AM

Last Annual 05/26/24 4:14 AM

First Periodic 05/11/24 1:38 AM

First Annual 05/26/24 4:14 AM

Ln 3: Diesel

Gross Test

Prev 24 Hours 13
Since Midnight 11

Last Gross 05/30/24 1:47 PM

Last Periodic 05/26/24 11:39 PM

Last Annual 05/03/24 2:51 AM

First Periodic 05/03/24 1:20 AM

First Annual 05/03/24 2:51 AM

Ln 4: K-1

Gross Test

Prev 24 Hours 0
Since Midnight 0

5/30/24 4:02 PM

obil
50 County Road 15
lkhart In

Sensor Status Report -
All Sensors

Sensor Location Status

1 Reg NL Stp Sump	NORMAL
2 Premium Stp Sump	NORMAL
3 Diesel Stp Sump	NORMAL
4 K-1 Stp Sump	NORMAL
5 NL / Prem Annula	NORMAL
6 Diesel/K-1 Annul	NORMAL

5/30/24 4:02 PM

obil
50 County Road 15
lkhart In

ANK LEAK TEST HISTORY -
PASSED TEST RESULTS

1: Regular Unleaded

REPORT TYPE	= LAST GROSS
DATE/TIME	= 05/30/24 10:20
METHOD	= SLD Gross Test
VG. VOLUME	= 7758
VOLUME	= 39.2

REPORT TYPE	= LAST PERIODIC
DATE/TIME	= 05/30/24 4:06
METHOD	= CSLD Periodic Test
HOURS	= 30
VG. VOLUME	= 12042
VOLUME	= 60.9

REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 05/04/24 4:08
METHOD	= CSLD Periodic Test
HOURS	= 27
VG. VOLUME	= 12668
VOLUME	= 64.0