

VACUUM = 13094
HOURS = 30
METHOD = C2FD 051
DWELLTIME = 00155
RELOUT

08/15/24 5:07 PM

Mobil
750 County Road 15
Elkhart In

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: Regular Unleaded

Gross Test

Prev 24 Hours 115
Since Midnight 89

Last Gross 08/15/24 5:05 PM

Last Periodic 08/14/24 2:52 AM

First Periodic 08/05/24 1:24 AM

Ln 2: Premium Unleaded

Gross Test

Prev 24 Hours 153
Since Midnight 131

Last Gross 08/15/24 5:04 PM

Last Periodic 08/14/24 2:51 AM

First Periodic 08/03/24 5:11 AM

Ln 3: Diesel

Gross Test

Prev 24 Hours 14
Since Midnight 12

Last Gross 08/15/24 2:01 PM

Last Periodic 08/12/24 10:40 AM

First Periodic 08/01/24 7:26 PM

Ln 4: K-1

Gross Test

Prev 24 Hours 0
Since Midnight 0

08/15/24 5:07 PM

Mobil
750 County Road 15
Elkhart In

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	Reg NL Stp Sump	NORMAL
L 2	Premium Stp Sump	NORMAL
L 3	Diesel Stp Sump	NORMAL
L 4	K-1 Stp Sump	NORMAL
L 5	NL / Prem Annula	NORMAL
L 6	Diesel/K-1 Annul	NORMAL

08/15/24 5:07 PM

Mobil
750 County Road 15
Elkhart In

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: Regular Unleaded

REPORT TYPE = LAST GROSS
DATE/TIME = 08/15/24 3:15
METHOD = SLD Gross Test
AVG. VOLUME = 6965
% VOLUME = 35.2

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/15/24 4:05
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 11604
% VOLUME = 58.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/10/24 1:45
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 13206
% VOLUME = 66.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/02/24 2:53
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 11906
% VOLUME = 60.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/22/24 6:29
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 13064

08/15/24 5:07 PM

Mobil
750 County Road 15
Elkhart In

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: Premium Unleaded

REPORT TYPE = LAST GROSS
DATE/TIME = 08/15/24 3:13
METHOD = SLD Gross Test
AVG. VOLUME = 2281
% VOLUME = 36.1

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/15/24 4:05
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 1993
% VOLUME = 31.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/15/24 4:05
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 1993
% VOLUME = 31.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/07/24 6:11
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 1584
% VOLUME = 25.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/01/24 5:41
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 2768
% VOLUME = 43.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/27/24 4:47
METHOD = CSLD Periodic Test
HOURS = 24

8/15/24 5:11 PM

obil
50 County Road 15
Alkhart In

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

3: Diesel

REPORT TYPE = LAST GROSS
DATE/TIME = 08/15/24 16:19
METHOD = SLD Gross Test
AVG. VOLUME = 1283
% VOLUME = 21.2

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/15/24 17:04
METHOD = CSLD Periodic Test
HOURS = 40
AVG. VOLUME = 1649
% VOLUME = 27.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/09/24 21:20
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 1999
% VOLUME = 33.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/19/24 6:00
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 3014
% VOLUME = 49.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/22/24 0:43
METHOD = CSLD Periodic Test
HOURS = 37

/15/24 5:08 PM

bil
0 County Road 15
khart In

ANK LEAK TEST HISTORY -
SSED TEST RESULTS

4: K-1

PORT TYPE = LAST GROSS
TE/TIME = 08/15/24 16:34
THOD = SLD Gross Test
G. VOLUME = 1512
VOLUME = 40.1

PORT TYPE = LAST PERIODIC
TE/TIME = 08/15/24 14:42
THOD = CSLD Periodic Test
OURS = 59
G. VOLUME = 1512
VOLUME = 40.1

PORT TYPE = FULLEST PERIODIC
TE/TIME = 08/08/24 23:16
THOD = CSLD Periodic Test
OURS = 76
G. VOLUME = 1512
VOLUME = 40.2

PORT TYPE = FULLEST PERIODIC
TE/TIME = 07/01/24 2:59
THOD = CSLD Periodic Test
OURS = 61
G. VOLUME = 1512
VOLUME = 40.2

PORT TYPE = FULLEST PERIODIC
TE/TIME = 06/30/24 17:58
THOD = CSLD Periodic Test
OURS = 66
G. VOLUME = 1512
VOLUME = 40.2

PORT TYPE = FULLEST PERIODIC
TE/TIME = 05/01/24 18:17
THOD = CSLD Periodic Test
OURS = 119
G. VOLUME = 1519
VOLUME = 40.4

PORT TYPE = FULLEST PERIODIC
TE/TIME = 04/13/24 21:44
THOD = CSLD Periodic Test
OURS = 91
G. VOLUME = 1521
VOLUME = 40.4

PORT TYPE = FULLEST PERIODIC