

12/23/24 4:20 PM

Mobil  
750 County Road 15  
Elkhart In

PRESSURE LINE LEAK REPORTS  
PASSED TESTS HISTORY

Ln 1: Regular Unleaded

Gross Test

Prev 24 Hours 99  
Since Midnight 74

Last Gross 12/23/24 4:19 PM  
Last Periodic 12/21/24 12:48 AM  
First Periodic 12/06/24 11:19 PM

Ln 2: Premium Unleaded

Gross Test

Prev 24 Hours 127  
Since Midnight 102

Last Gross 12/23/24 4:16 PM  
Last Periodic 12/22/24 8:05 AM  
First Periodic 12/06/24 11:22 PM

Ln 3: Diesel

Gross Test

Prev 24 Hours 16  
Since Midnight 15

Last Gross 12/23/24 2:19 PM  
Last Periodic 12/22/24 1:48 PM  
First Periodic 12/03/24 12:35 AM

Ln 4: K-1

Gross Test

Prev 24 Hours 0  
Since Midnight 0

Last Gross 12/16/24 4:05 PM  
Last Periodic 12/16/24 4:39 PM  
Last Annual 12/01/24 12:56 AM  
First Periodic 12/01/24 12:37 AM  
First Annual 12/01/24 12:56 AM

12/23/24 4:21 PM

Mobil  
750 County Road 15  
Elkhart In

Sensor Status Report -  
All Sensors

| #   | Sensor Location  | Status |
|-----|------------------|--------|
| L 1 | Reg NL Stp Sump  | NORMAL |
| L 2 | Premium Stp Sump | NORMAL |
| L 3 | Diesel Stp Sump  | NORMAL |
| L 4 | K-1 Stp Sump     | NORMAL |
| L 5 | NL / Prem Annula | NORMAL |
| L 6 | Diesel/K-1 Annul | NORMAL |

12/23/24 4:21 PM

Mobil  
750 County Road 15  
Elkhart In

TANK LEAK TEST HISTORY -  
PASSED TEST RESULTS

T 1: Regular Unleaded

REPORT TYPE = LAST GROSS  
DATE/TIME = 12/23/24 3:05  
METHOD = SLD Gross Test  
AVG. VOLUME = 12070  
% VOLUME = 61.0

REPORT TYPE = LAST PERIODIC  
DATE/TIME = 12/23/24 0:41  
METHOD = CSLD Periodic Test  
HOURS = 20  
AVG. VOLUME = 11761  
% VOLUME = 59.5

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 12/07/24 5:52  
METHOD = CSLD Periodic Test  
HOURS = 34  
AVG. VOLUME = 13031  
% VOLUME = 65.9

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 11/24/24 8:13  
METHOD = CSLD Periodic Test  
HOURS = 29  
AVG. VOLUME = 13181  
% VOLUME = 66.6

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 10/30/24 3:28  
METHOD = CSLD Periodic Test  
HOURS = 23  
AVG. VOLUME = 11795  
% VOLUME = 59.6

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 09/18/24 3:56  
METHOD = CSLD Periodic Test  
HOURS = 31  
AVG. VOLUME = 11345  
% VOLUME = 57.3

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 08/10/24 1:45  
METHOD = CSLD Periodic Test  
HOURS = 26  
AVG. VOLUME = 13206  
% VOLUME = 66.8

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 07/02/24 2:53  
METHOD = CSLD Periodic Test  
HOURS = 26  
AVG. VOLUME = 11906  
% VOLUME = 60.2

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 06/22/24 6:29

12/23/24 4:21 PM

obil  
50 County Road 15  
Alkhart In

TANK LEAK TEST HISTORY -  
PASSED TEST RESULTS

3: Diesel

REPORT TYPE = LAST GROSS  
DATE/TIME = 12/23/24 15:36  
METHOD = SLD Gross Test  
WG. VOLUME = 1890  
VOLUME = 31.3

REPORT TYPE = LAST PERIODIC  
DATE/TIME = 12/23/24 7:40  
METHOD = CSLD Periodic Test  
OURS = 46  
WG. VOLUME = 2335  
VOLUME = 38.6

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 12/01/24 0:42  
METHOD = CSLD Periodic Test  
OURS = 57  
WG. VOLUME = 2997  
VOLUME = 49.6

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 11/28/24 3:17  
METHOD = CSLD Periodic Test  
OURS = 45  
WG. VOLUME = 3633  
VOLUME = 60.1

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 10/31/24 10:14  
METHOD = CSLD Periodic Test  
OURS = 36  
WG. VOLUME = 3005  
VOLUME = 49.7

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 09/20/24 21:40  
METHOD = CSLD Periodic Test  
OURS = 31  
WG. VOLUME = 4190  
VOLUME = 69.3

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 08/29/24 20:52  
METHOD = CSLD Periodic Test  
OURS = 34  
WG. VOLUME = 2168

12/23/24 4:21 PM

Mobil  
750 County Road 15  
Elkhart In

TANK LEAK TEST HISTORY -  
PASSED TEST RESULTS

T 4: K-1

REPORT TYPE = LAST GROSS  
DATE/TIME = 12/23/24 15:47  
METHOD = SLD Gross Test  
AVG. VOLUME = 1443  
% VOLUME = 38.3

REPORT TYPE = LAST PERIODIC  
DATE/TIME = 12/23/24 14:11  
METHOD = CSLD Periodic Test  
HOURS = 68  
AVG. VOLUME = 1444  
% VOLUME = 38.4

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 12/01/24 22:04  
METHOD = CSLD Periodic Test  
HOURS = 73  
AVG. VOLUME = 1471  
% VOLUME = 39.1

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 11/01/24 3:07  
METHOD = CSLD Periodic Test  
HOURS = 86  
AVG. VOLUME = 1481  
% VOLUME = 39.3

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 10/01/24 14:37  
METHOD = CSLD Periodic Test  
HOURS = 61  
AVG. VOLUME = 1497  
% VOLUME = 39.8

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 09/01/24 5:57  
METHOD = CSLD Periodic Test  
HOURS = 74  
AVG. VOLUME = 1512  
% VOLUME = 40.2

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 08/31/24 23:56  
METHOD = CSLD Periodic Test  
HOURS = 74  
AVG. VOLUME = 1512  
% VOLUME = 40.2

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 07/01/24 2:59  
METHOD = CSLD Periodic Test  
HOURS = 61  
AVG. VOLUME = 1512  
% VOLUME = 40.2

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 06/30/24 17:58  
METHOD = CSLD Periodic Test  
HOURS = 66  
AVG. VOLUME = 1512  
% VOLUME = 40.2