

07/14/24 5:01 PM

Abill
750 County Road 15
Elkhart In

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: Regular Unleaded

Gross Test
Prev 24 Hours 75
Since Midnight 50

Last Gross 07/14/24 4:58 PM
Last Periodic 07/13/24 3:48 AM

First Periodic 07/03/24 3:29 AM

Ln 2: Premium Unleaded

Gross Test
Prev 24 Hours 84
Since Midnight 54

Last Gross 07/14/24 4:56 PM
Last Periodic 07/13/24 3:49 AM

First Periodic 07/03/24 3:29 AM

Ln 3: Diesel

Gross Test
Prev 24 Hours 3
Since Midnight 3

Last Gross 07/14/24 1:23 PM
Last Periodic 07/13/24 11:25 AM

First Periodic 07/01/24 1:39 PM

Ln 4: K-1

Gross Test
Prev 24 Hours 0
Since Midnight 0

07/14/24 5:01 PM

Wobill
750 County Road 15
Elkhart In

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	Reg NL Stp Sump	NORMAL
L 2	Premium Stp Sump	NORMAL
L 3	Diesel Stp Sump	NORMAL
L 4	K-1 Stp Sump	NORMAL
L 5	NL / Prem Annula	NORMAL
L 6	Diesel/K-1 Annul	NORMAL

07/14/24 5:01 PM

Wobill
750 County Road 15
Elkhart In

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: Regular Unleaded

REPORT TYPE = LAST GROSS
DATE/TIME = 07/14/24 7:32
METHOD = SLD Gross Test
AVG. VOLUME = 12122
% VOLUME = 61.3

REPORT TYPE = LAST PERIODIC
DATE/TIME = 07/14/24 8:36
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 10522
% VOLUME = 53.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/02/24 2:53
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 11906
% VOLUME = 60.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/22/24 6:29
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 13064
% VOLUME = 66.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/04/24 4:08
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 12668
% VOLUME = 64.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/13/24 6:51
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 13169
% VOLUME = 66.6