

10/28/24 5:06 PM

Mobil
750 County Road 15
Elkhart In

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: Regular Unleaded

Gross Test
Prev 24 Hours 90
Since Midnight 78
Last Gross 10/28/24 4:57 PM
Last Periodic 10/26/24 12:50 AM
First Periodic 10/02/24 2:17 AM

Ln 2: Premium Unleaded

Gross Test
Prev 24 Hours 110
Since Midnight 97
Last Gross 10/28/24 4:56 PM
Last Periodic 10/27/24 8:41 PM
First Periodic 10/08/24 2:15 AM

Ln 3: Diesel

Gross Test
Prev 24 Hours 15
Since Midnight 15
Last Gross 10/28/24 4:09 PM
Last Periodic 10/27/24 2:44 PM
First Periodic 10/03/24 3:04 PM

Ln 4: K-1

Gross Test
Prev 24 Hours 0
Since Midnight 0
Last Gross 10/26/24 8:40 AM
Last Periodic 10/17/24 8:26 AM
First Periodic 10/17/24 8:26 AM

10/28/24 5:06 PM

Mobil
750 County Road 15
Elkhart In

Sensor Status Report -
All Sensors

Sensor Location Status

1 Reg NL Stp Sump NORMAL
2 Premium Stp Sump NORMAL
3 Diesel Stp Sump NORMAL
4 K-1 Stp Sump NORMAL
5 NL / Prem Annula NORMAL
6 Diesel/K-1 Annul NORMAL

10/28/24 5:06 PM

obil
50 County Road 15
Elkhart In

ANK LEAK TEST HISTORY -
PASSED TEST RESULTS

1: Regular Unleaded

REPORT TYPE = LAST GROSS
DATE/TIME = 10/28/24 2:37
METHOD = SLD Gross Test
VG. VOLUME = 13795
VOLUME = 69.7

REPORT TYPE = LAST PERIODIC
DATE/TIME = 10/28/24 3:15
METHOD = CSLD Periodic Test
DOURS = 25
VG. VOLUME = 11280
VOLUME = 57.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/27/24 5:46
METHOD = CSLD Periodic Test
DOURS = 23
VG. VOLUME = 11507
VOLUME = 58.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/18/24 3:56
METHOD = CSLD Periodic Test
DOURS = 31
VG. VOLUME = 11345
VOLUME = 57.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/10/24 1:45
METHOD = CSLD Periodic Test
DOURS = 26
VG. VOLUME = 13206
VOLUME = 66.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/02/24 2:53
METHOD = CSLD Periodic Test
DOURS = 26
VG. VOLUME = 11906
VOLUME = 60.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/22/24 6:29
METHOD = CSLD Periodic Test
DOURS = 30
VG. VOLUME = 13064
VOLUME = 66.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/04/24 4:08
METHOD = CSLD Periodic Test
DOURS = 27
VG. VOLUME = 12668
VOLUME = 64.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/13/24 6:51
METHOD = CSLD Periodic Test
DOURS = 26
VG. VOLUME = 13169
VOLUME = 66.6

Elkhart In
120 Cornish Road
10001

3/28/24 5:06 PM

abil
50 County Road 15
lkhart In

ANK LEAK TEST HISTORY -
ASSED TEST RESULTS

2: Premium Unleaded

EPORT TYPE = LAST GROSS
ATE/TIME = 10/28/24 10:51
ETHOD = SLD Gross Test
VG. VOLUME = 3258
VOLUME = 51.5

EPORT TYPE = LAST PERIODIC
ATE/TIME = 10/28/24 3:15
ETHOD = CSLD Periodic Test
OURS = 27
VG. VOLUME = 2729
VOLUME = 43.2

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 10/27/24 22:11
ETHOD = CSLD Periodic Test
OURS = 25
VG. VOLUME = 2780
VOLUME = 44.0

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 09/30/24 3:11
ETHOD = CSLD Periodic Test
OURS = 30
VG. VOLUME = 2226
VOLUME = 35.2

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 08/30/24 1:45
ETHOD = CSLD Periodic Test
OURS = 30
VG. VOLUME = 2195
VOLUME = 34.7

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 07/07/24 6:11
ETHOD = CSLD Periodic Test
OURS = 29
VG. VOLUME = 1584
VOLUME = 25.1

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 06/01/24 5:41
ETHOD = CSLD Periodic Test
OURS = 25
VG. VOLUME = 2768
VOLUME = 43.8

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 05/27/24 4:47
ETHOD = CSLD Periodic Test
OURS = 24
VG. VOLUME = 2807
VOLUME = 44.4

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 04/07/24 3:01
ETHOD = CSLD Periodic Test
OURS = 25
VG. VOLUME = 2114
VOLUME = 33.4

EPORT TYPE = FULLEST PERIODIC

3: Diesel

EPORT TYPE = LAST GROSS
 ATE/TIME = 10/28/24 16:24
 ETHOD = SLD Gross Test
 VG. VOLUME = 3212
 VOLUME = 53.1

EPORT TYPE = LAST PERIODIC
 ATE/TIME = 10/28/24 15:19
 ETHOD = CSLD Periodic Test
 OURS = 57
 VG. VOLUME = 2934
 VOLUME = 48.5

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 10/28/24 15:19
 ETHOD = CSLD Periodic Test
 OURS = 57
 VG. VOLUME = 2934
 VOLUME = 48.5

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 09/20/24 21:40
 ETHOD = CSLD Periodic Test
 OURS = 31
 VG. VOLUME = 4190
 VOLUME = 69.3

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 08/29/24 20:52
 ETHOD = CSLD Periodic Test
 OURS = 34
 VG. VOLUME = 2168
 VOLUME = 35.9

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 07/19/24 6:00
 ETHOD = CSLD Periodic Test
 OURS = 38
 VG. VOLUME = 3014
 VOLUME = 49.9

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 06/22/24 0:43
 ETHOD = CSLD Periodic Test
 OURS = 33
 VG. VOLUME = 2859
 VOLUME = 47.3

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 05/11/24 12:46
 ETHOD = CSLD Periodic Test
 OURS = 35
 VG. VOLUME = 3241
 VOLUME = 53.6

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 04/27/24 6:26
 ETHOD = CSLD Periodic Test
 OURS = 34
 VG. VOLUME = 3099
 VOLUME = 51.3

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 03/21/24 7:24
 ETHOD = CSLD Periodic Test
 OURS = 35
 VG. VOLUME = 4112
 VOLUME = 68.0

EPORT TYPE = FULLEST PERIODIC
 ATE/TIME = 02/17/24 21:57
 ETHOD = CSLD Periodic Test
 OURS = 40
 VG. VOLUME = 3023
 VOLUME = 50.0

0/28/24 5:06 PM

obil
50 County Road 15
lkhart In

ANK LEAK TEST HISTORY -
ASSED TEST RESULTS

4: K-1

EPORT TYPE = LAST GROSS
ATE/TIME = 10/28/24 16:12
ETHOD = SLD Gross Test
VG. VOLUME = 1481
VOLUME = 39.3

EPORT TYPE = LAST PERIODIC
ATE/TIME = 10/28/24 14:53
ETHOD = CSLD Periodic Test
OURS = 76
VG. VOLUME = 1482
VOLUME = 39.3

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 10/01/24 14:37
ETHOD = CSLD Periodic Test
OURS = 61
VG. VOLUME = 1497
VOLUME = 39.8

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 09/01/24 5:57
ETHOD = CSLD Periodic Test
OURS = 74
VG. VOLUME = 1512
VOLUME = 40.2

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 08/31/24 23:56
ETHOD = CSLD Periodic Test
OURS = 74
VG. VOLUME = 1512
VOLUME = 40.2

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 07/01/24 2:59
ETHOD = CSLD Periodic Test
OURS = 61
VG. VOLUME = 1512
VOLUME = 40.2

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 06/30/24 17:58
ETHOD = CSLD Periodic Test
OURS = 66
VG. VOLUME = 1512
VOLUME = 40.2

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 05/01/24 18:17
ETHOD = CSLD Periodic Test
OURS = 119
VG. VOLUME = 1519
VOLUME = 40.4

EPORT TYPE = FULLEST PERIODIC
ATE/TIME = 04/13/24 21:44