

02/02/24 12:00 PM

Mobil
750 County Road 15
Elkhart In

Sensor Status Report -
All Sensors

Sensor Location Status

L 1 Reg NL Stp Sump NORMAL
L 2 Premium Stp Sump NORMAL
L 3 Diesel Stp Sump NORMAL
L 4 K-1 Stp Sump NORMAL
L 5 NL / Prem Annula NORMAL
L 6 Diesel/K-1 Annul NORMAL

02/02/24 12:01 PM

Mobil
750 County Road 15
Elkhart In

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: Regular Unleaded

Gross Test
Prev 24 Hours 93
Since Midnight 47

Last Gross 02/02/24 11:47 AM

Ln 2: Premium Unleaded

Gross Test
Prev 24 Hours 127
Since Midnight 58

Last Gross 02/02/24 11:54 AM

Ln 3: Diesel

Gross Test
Prev 24 Hours 19
Since Midnight 11

Last Gross 02/02/24 11:57 AM

Last Periodic 02/02/24 11:46 AM

First Periodic 02/02/24 11:46 AM

Ln 4: K-1

Gross Test
Prev 24 Hours 1
Since Midnight 0

Last Gross 02/01/24 4:53 PM

02/02/24 12:01 PM

Mobil
750 County Road 15
Elkhart In

ANK LEAK TEST HISTORY -
PASSED TEST RESULTS

1: Regular Unleaded

REPORT TYPE = LAST GROSS
ATE/TIME = 02/02/24 1:26
ETHOD = SLD Gross Test
OURS = 8077
VG. VOLUME = 43.9
VOLUME = 43.9

REPORT TYPE = LAST PERIODIC
ATE/TIME = 02/02/24 2:02
ETHOD = CSLD Periodic Test
OURS = 29
VG. VOLUME = 14979
VOLUME = 75.7

REPORT TYPE = FULLEST PERIODIC
ATE/TIME = 02/02/24 2:02
ETHOD = CSLD Periodic Test
OURS = 29
VG. VOLUME = 14979
VOLUME = 75.7

REPORT TYPE = FULLEST PERIODIC
ATE/TIME = 01/31/24 3:35
ETHOD = CSLD Periodic Test
OURS = 29
VG. VOLUME = 14979
VOLUME = 75.7

REPORT TYPE = FULLEST PERIODIC
ATE/TIME = 12/02/23 3:54
ETHOD = CSLD Periodic Test
OURS = 32
VG. VOLUME = 14873
VOLUME = 75.2

REPORT TYPE = FULLEST PERIODIC
ATE/TIME = 11/27/23 0:38
ETHOD = CSLD Periodic Test
OURS = 31
VG. VOLUME = 14954
VOLUME = 75.6

REPORT TYPE = FULLEST PERIODIC
ATE/TIME = 10/19/23 2:54
ETHOD = CSLD Periodic Test
OURS = 14
VG. VOLUME = 13898
VOLUME = 70.3

REPORT TYPE = FULLEST PERIODIC