

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

03/31/2023 2:44 PM

SCALO TEST REPORT

UNLEAD 12033.0 GAL
UNLEADED

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 12:11 AM
TEST STARTED 03/29/2023
STATUS 4000.02
TEST ENDED 2:37 AM
TEST ENDED 03/29/2023

SLOPE -0.068 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DIESEL 10153.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 7:54 AM
TEST STARTED 03/31/2023
STATUS 0.02
TEST ENDED 11:19 AM
TEST ENDED 03/31/2023

SLOPE -0.034 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 12033.0 GAL
PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 10:03 AM
TEST STARTED 03/31/2023
STATUS 11001.02
TEST ENDED 12:15 PM
TEST ENDED 03/31/2023

SLOPE -0.072 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

03/31/2023 2:44 PM

LEAK TEST REPORT

UNLEAD 12033.0 GAL
UNLEADED

END TIME 12:32 AM
END DATE 09/04/2019
TEST RESULT ABORTED
REASON DISPENSE

DIESEL 10153.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 95.0%
TEST STARTED 12:30 AM
TEST STARTED 09/04/2019
END TIME 5:14 AM
END DATE 09/04/2019
LEVEL 30.6 IN
GROSS 2789.3 GAL
TEMP 73.2 F
TEST RESULT PASSED

PREMIUM 12033.0 GAL
PREMIUM

LEAK TEST 0.200 GPH