

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

01/31/2023 3:04 PM

SCALD TEST REPORT

UNLEAD 12033.0 GAL
UNLEADED

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 1:56 AM
TEST STARTED 01/31/2023
STATUS 1000.02
TEST ENDED 5:31 AM
TEST ENDED 01/31/2023

SLOPE -0.021 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DIESEL 10153.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 12:45 PM
TEST STARTED 01/31/2023
STATUS 0.02
TEST ENDED 2:54 PM
TEST ENDED 01/31/2023

SLOPE 0.003 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 12033.0 GAL
PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 6:13 AM
TEST STARTED 01/31/2023
STATUS 0.02
TEST ENDED 8:21 AM
TEST ENDED 01/31/2023

SLOPE 0.001 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

01/31/2023 3:05 PM

LEAK TEST REPORT

UNLEAD 12033.0 GAL

UNLEADED

END TIME 12:32 AM
END DATE 02/04/2023