

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

02/15/2023 5:18 PM

SCALD TEST REPORT

UNLEAD 12033.0 GAL
UNLEADED

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 2:14 AM
TEST STARTED 02/13/2023
STATUS 0.02
TEST ENDED 6:11 AM
TEST ENDED 02/13/2023

SLOPE -0.035 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DIESEL 10153.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 1:28 PM
TEST STARTED 02/15/2023
STATUS 0.02
TEST ENDED 3:38 PM
TEST ENDED 02/15/2023

SLOPE 0.026 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 12033.0 GAL
PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 4:30 AM
TEST STARTED 02/15/2023
STATUS 2000.02
TEST ENDED 6:38 AM
TEST ENDED 02/15/2023

SLOPE -0.058 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

02/15/2023 5:18 PM

ELKHART IN
1245 S MAIN

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

02/15/2023 5:16 PM

PRODUCT DELIVERY SUMMARY

(GROSS VOLUME)

UNLEADED 12033.0 GAL

UNLEAD

12/14/2022	8312.5 GAL
12/18/2022	7275.1 GAL
12/22/2022	8268.9 GAL
12/30/2022	8337.1 GAL
01/07/2023	8264.6 GAL
01/21/2023	7021.0 GAL
01/26/2023	7024.3 GAL
02/03/2023	8338.8 GAL
02/09/2023	8355.0 GAL
02/13/2023	8266.5 GAL

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

02/15/2023 5:18 PM

LEAK TEST REPORT

UNLEAD 12033.0 GAL

UNLEADED

END TIME	12:32 AM
END DATE	09/04/2019
TEST RESULT	ABORTED
REASON	DISPENSE

DIESEL 10153.0 GAL

DIESEL

LEAK TEST	0.200 GPH
LEAK THRESHOLD	0.100 GPH
CONFIDENCE LEVEL	95.0%
TEST STARTED	12:30 AM
TEST STARTED	09/04/2019
END TIME	5:14 AM
END DATE	09/04/2019
LEVEL	30.6 IN
GROSS	2789.3 GAL
TEMP	73.2 F
TEST RESULT	PASSED

PREMIUM 12033.0 GAL

PREMIUM

LEAK TEST	0.200 GPH
LEAK THRESHOLD	0.100 GPH
CONFIDENCE LEVEL	95.0%
TEST STARTED	12:30 AM
TEST STARTED	09/04/2019
END TIME	5:44 AM
END DATE	09/04/2019
LEVEL	24.9 IN
GROSS	2516.0 GAL
TEMP	73.9 F
TEST RESULT	PASSED