

Tanks Data		30 DAYS WALK THROUGH INSPECTION		
UST Facility I.D. (FID) # 1633		Contact Number		
Facility Name Conoco		Contact email		
Address 1245 S Main St Elkhart 46516		Date of Inspection 3/31/23		
Operator on Duty Name		Name of the Person Conducting Inspection Josh Rider		
Operator Training				
Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	
Registration/Notification Form				
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	
Release Detection				
Release Detection Method	☒ ATG ☐ CIM ☐ SIR		☐ IC ☐ Other	
Make and Model	Franklin FS TS-1001			
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No	
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No	
Interstitial Monitoring Sensor Status Normal	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No	
Spill Buckets				
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No	
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No	
Fill Ports				
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No	
Piping/STP Sumps				
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No	
Under Dispenser Containments (UDC)				
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No	
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.				
Operator on Duty Name		Signature		Date
317-645-0215		tanksdata@gmail.com		www.tanksdata.com