

Is it in Alarm mode?
Necessary Monitoring Sensor Status Normal
Necessary Monthly Printout Taken

FFS ☒ Yes ☐ No
TIM ☒ Yes ☐ No
TS-1001 ☒ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

UST Facility I.D. (FID) #

Facility Name

Address

Operator on Duty Name

30 DAYS WALK THROUGH INSPECTION

Operator Training current

Registration current with correct owner, operator etc.

Release Detection Method

Make and Model

Does it have paper?

Is it in Alarm mode?

Intermittent Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Are Spill Buckets Clean and free from water, debris, product etc?

Are the Spill Bucket in good condition and free of damage/cracks

Is Fill pipe cap tight and fill pipe free from any obstruction?

Are Sumps Clean and free from water, debris, product etc?

Are UDCs clean and free from water, debris, product etc?

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

www.tanksdata.com