

UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: Singh Brothers Petroleum
 OWNER ADDRESS: 1245 S Main Street
 OWNER CITY/STATE/ZIP: Elkhart, IN 46516

TESTING DATE: 10/10/2023

LOCATION NAME: Conoco Elkhart
 LOCATION ADDRESS: 1245 S Main Street
 LOCATION CITY/STATE: Elkhart, IN 46516
 LOCATION FID#: 01633

METHOD OF TANK LEAK DETECTION -
 METHOD OF PIPING LEAK DETECTION -
 TYPE OF UNDERGROUND PIPING -

ANNUAL TESTING/INSPECTIONS

AUTOMATIC TANK GAUGE TEST

NOT PERFORMED

TANK NO	PRODUCT	BRAND/MODEL	RESULT

PRODUCT LINE TEST

COMPLETED

LINE NO	PRODUCT	RESULT	AMT OF CHG/GPH
1	RUL	PASS	0
3	PUL	FAIL	-0.0888
2	DSL	PASS	0

Product line must be within manufacturer's criteria of +/- .050 GPH.

LEAK DETECTOR TEST

COMPLETED

LINE NO	PRODUCT	TYPE	RESULT
1	RUL	MLLD	PASS
2	DSL	MLLD	PASS
3	PUL	MLLD	FAIL

LIQUID SENSOR FUNCTIONALITY TEST

NOT PERFORMED

LOCATION	PRODUCT	TYPE	RESULT

LEGEND:

RUL	Regular Unleaded
DSL	Diesel
PUL	Premium Unleaded
KER	Kerosene
ODSL	Off Road Diesel
REC	Recreational

RECOMMENDATIONS:



CERTIFICATION VERIFICATION

Singh Brothers Petroleum
1245 S Main Street
Elkhart, IN 46516


Testing Date: 10/10/2023
Location of Test: Conoco Elkhart
1245 S Main Street
Elkhart, IN 46516
Site FID#: 01633
Service Technician:
Certified Technician: PATRICK FOLEY

0

Midwest ECS has completed the following tests/inspections at the above noted location:

ATG Functionality	
Leak Detector	X
Elec Line Leak Detector	
Product Line Testing	X
Liquid Sensor Functionality	
Spill Bucket	
Containment Hydrostatic Sump	
Overfill Equipment Inspection	
Overfill Alarm	
Vent Valve	
Interstitial	
Non-Volumetric Tank Tightness	
Shear Valve Inspection	

I, PATRICK FOLEY, the certified technician, was present throughout the duration of the testing and/or inspection performed by Midwest ECS at the above address on the above date. I affirm that the testing was done in accordance with Rule 329 IAC 9 and 40CFR Part 80, is accurate based upon the results received and that these forms accurately reflect the results of the testing and/or inspection.

Technician Signature: 

Technician Printed Name: PATRICK FOLEY

Date & Time: 10/10/2023 1:41



INDIANA HOMELAND SECURITY

Underground Storage Tank

PATRICK FOLEY
602 S 21ST STREET
LAFAYETTE, INDIANA

STATE/PERMIT #	ISSUE	EFFECTIVE	EXPIRATION
UC111246	09/15/2022	09/16/2022	09/15/2024

DISCIPLINES

☒ Installation or Retrofitting	☐ Decommissioning Closure
☐ Cathodic Protection	☐ Decommissioning Removal

I attest with my signature below, that this technician was present onsite for testing as described above.