

APPENDIX C-7 AUTOMATIC TANK GAUGE OPERATION INSPECTION

TEST DATE:	8/29	/2023	OWNER NAME:		Tanks Data
	Citgo Elkhart				1245 South Main Street
	1245 South Main Street		OWNER CITY/STATE/ZIP:		
	Elkhart, IN 46516		· · · · · · · · ·		
LOCATION PHONE:			_	LOCATION FID#:	01633
			WORK ORDER NO:		
			•	_	
This procedure is to determine whether the	automatice	tank guage (AT	G) is operting (nronerly See PFI/I	RP1200 Section 8.2 for the
inspection procedure. The procedure is ap					
Tank Number	1	2	3		, , , , , , , , , , , , , , , , , , ,
Product Stored	RUL	DSL	PUL		
ATG Brand and Model	INCON	INCON	INCON		
1. Tank Volume, gallons	11,401	9,625	11,430		
2. Tank Diameter, inches	96"	96"	96"		
3. After removing the ATG from the tank, it nas been inspected and any damaged or missing parts replaced?	yes	yes	no		
4. Float moves freely on the stem without pinding?	yes	yes	no		
5. Fuel float level agrees with the value programmed into the console?	yes	yes	no		
6. Water float level agrees with the value programmed into the console?	yes	yes	no		
7. Inch level from bottom of stem when 90% alarm is triggered.	86.4	86.4	no		
8. Inch level at which the overfill alarm activates corresponds with the valve programmed in the gauge?	yes	yes	no		
9. Inch level from bottom when the water loat first triggers an alarm.	2"	2"	х		
10. Inch level at which the water float alarm activates corresponds with the valve programmed in the gauge?	yes	yes	no		
f any answers in Lines 3, 4, 5, or 6 are "No'	, the system	hs failed the te	st.		
TEST RESULTS	PASS	PASS	FAIL		
COMMENTS:					I.
		E TO DENAOVE EV	ATC DDCCC		
* All liquids must be disposed of properly.	UNABL	E TO REMOVE PUL	AIG PKUBE		
0					
SERVICE TECHNICIAN NAME (printe	ed)	-		SERVICE TECHNICIA	IN SIGNATURE
RONNIE BROWN			Ron	nw B) Ngw ~
CERTIFIED TECHNICIAN NAME (print	ed)	•	. •	CERTIFIED TECHNICI	AN SIGNATURE CERT NO: UC11225 EXPIRATION DATE: 01/23/202